



**MANITOUWADGE**  
ONTARIO • CANADA

**Manitouwadge Public Works  
Presents:**

**Manitouwadge Water Treatment Plant  
Water Treatment Subsystem Class I**

**And**

**Manitouwadge Water Distribution  
Water Distribution Subsystem Class I**

**2013**

**ANNUAL REPORT**

**Prepared by: Kirk Tourout and Paul Richard**

**Date: February 11, 2014**

**Township of Manitowadge  
Public Works Department  
Manitowadge Water Treatment Plant  
Water Treatment Subsystem Class I  
And  
Manitowadge Water Distribution  
Water Distribution Subsystem Class I**

**TABLE OF CONTENTS**

<b>TOPIC</b>	<b>PAGE NUMBER</b>
List of Appendices _____	I – III
1.0 Introduction _____	1
2.0 Manitowadge Water Works _____	2
2.1 Water Source _____	2
2.2 History _____	2 – 5
2.3 Operations _____	5
2.4 Decreasing Demand _____	5
2.5 Well Pumps _____	6
2.6 Pump Setup _____	6
3.0 Water Quality _____	7
4.0 Some Water Facts _____	7
4.1 Data _____	7 - 8
4.2 Water Metering _____	8
5.0 Compliance Issues _____	9

5.1 Sampling	9
5.2 Peak Flows	9 - 10
6.0 Certificate of Approval	10
6.1 Daily Laboratory Testing and Operational Parameters	10
6.2 Flow Metring	10 - 11
6.3 Lead Sampling	11
6.4 UV Treatment Operations and Data	11 - 12
7.0 Ministry Orders	13
8.0 Conclusion	13 - 14
Recommendations	15

## APPENDICES

<u>NUMBER</u>	<u>TITLE</u>
A-1	Summary of Sodium Hypochlorite
A-2	Summary of Monthly Actual and Peak Flows
A-3	Summary of Maximum and Minimum Daily Flow Events
A-4	Summary of Maximum and Minimum Peak Flow Events
A-5	Summary of Annual Actual Daily Flows
A-6	Summary of Annual Instantaneous Maximum Daily Flows
A-7	Summary of Annual Instantaneous Minimum Daily Flows
B-1	Ontario Regulation 170/03 Annual Sampling Requirement- Inorganics
B-2	Ontario Regulation 170/03 Annual Sampling Requirement- Organics
B-3	Ontario Regulation 170/03 Quarterly Sampling Requirement
B-4a	Drinking Water Surveillance Program Chemical, Physical and Operational Parameters-Raw Water
B-4b	Drinking Water Surveillance Program Chemical, Physical and Operational Parameters-Treated Water
B-5a	Drinking Water Surveillance Program- Inorganics - Raw Water
B-5b	Drinking Water Surveillance Program- Inorganics - Treated Water
C-1	Ontario Regulation 170/03 Bacteriological Sampling Requirement Monthly Summary – Raw Water
C-2	Ontario Regulation 170/03 Bacteriological Sampling Requirement Monthly Summary – Treated Water
C-3	Ontario Regulation 170/03 Bacteriological Sampling Requirement Monthly Summary – Distribution System

**NUMBER**

**TITLE**

**D-1** Summary of Monthly Laboratory Testing and Operational Parameters:

- a) Turbidity
- b) Colour
- c) Temperature
- d) pH
- e) Free Chlorine Residual
- f) Total Chlorine Residual
- g) Raw Well Turbidity Readings

- D-1g Zone 1 FC:** Zone #1 – Free Chlorine Residual
- D-1g Zone 1 TC:** Zone #1 – Total Chlorine Residual
- D-1g Zone 1 pH:** Zone #1 – pH
- D-1g Zone 2 FC:** Zone #2 – Free Chlorine Residual
- D-1g Zone 2 TC:** Zone #2 – Total Chlorine Residual
- D-1g Zone 2 pH:** Zone #2 – pH
- D-1g Zone 3 FC:** Zone #3 – Free Chlorine Residual
- D-1g Zone 3 TC:** Zone #3 – Total Chlorine Residual
- D-1g Zone 3 pH:** Zone #3 – pH
- D-1g Zone 4 FC:** Zone #4 – Free Chlorine Residual
- D-1g Zone 4 TC:** Zone #4 – Total Chlorine Residual
- D-1g Zone 4 pH:** Zone #4 – pH

**D-2** Summary of Monthly Daily On-Line Instrumentation

- a) Turbidity
- b) Free Chlorine Residual
- c) pH
- d) Temperature
- e) UV Annual (min, max and average)

**NUMBER**

**TITLE**

<b>E-1</b>	Annual Summary
<b>E-2</b>	Daily Flows - January
<b>E-3</b>	Daily Flows - February
<b>E-4</b>	Daily Flows - March
<b>E-5</b>	Daily Flows - April
<b>E-6</b>	Daily Flows - May
<b>E-7</b>	Daily Flows - June
<b>E-8</b>	Daily Flows - July
<b>E-9</b>	Daily Flows - August
<b>E-10</b>	Daily Flows - September
<b>E-11</b>	Daily Flows - October
<b>E-12</b>	Daily Flows - November
<b>E-13</b>	Daily Flows - December
<b>F</b>	Glossary of Terms

**ANNUAL REPORT  
2013  
Township of Manitowadge  
Public Works Department  
Manitowadge Water Treatment Plant  
Water Treatment Subsystem Class 1  
and  
Manitowadge Water Distribution  
Water Distribution Subsystem Class 1**

**1.0 INTRODUCTION**

The Corporation of the Township of Manitowadge Public Works Department operates the Manitowadge Water Distribution System under a Drinking Water Works Permit # 229-201 issued by the Ministry of the Environment.

The Corporation of the Township of Manitowadge is required to produce an annual compliance report for the benefit of the Ministry of the Environment and the residents of Manitowadge within ninety days of the end of the calendar year.

Contained in this report, you will find the water quality data and information that we are required to keep and publish, under the Ontario Drinking Water Protection Act, from January 1, 2013 to December 31, 2013 As well; we include some of our accomplishments during the year.

Appendices to this report are the summaries of the laboratory results mandated by Ontario Regulation 170/03. Parameters included are microbiological, chemical and operational, daily laboratory testing, daily on-line instrumentation readings, inorganics and organics. As well, we have attached a "Glossary of Terms" to aid you in interpreting the data presented.

While perusing these appendices please be sure to read any and all the attached footnotes remembering that not all Maximum Acceptable Concentrations or Interim Maximum Acceptable Concentrations are health related. In fact some are aesthetic or operational parameters. Remember also that the presence of any substance does "not necessarily make the water unsafe to drink".

As of November 30, 2005 our facilities are classified as a Class I Water Treatment Subsystem and a Class I Water Distribution Subsystem.

Kirk Tourout is the operator in overall responsible charge. He is currently licensed as a Class I Water Treatment Subsystem and a Class II Water Distribution and Supply Subsystem operator. Kirk is assisted by Paul Richard who is currently licensed as a Class

I Water Treatment Subsystem and a Class I Water Distribution and Supply Subsystem operator.

Our system participates as part of the Ontario Drinking Water Surveillance Program which occurs twice annually.

Our Laboratory analysis for Ontario Regulation 170/03 sampling requirements are performed by Thunder Bay Analytical a division of ALS Laboratory Group who are accredited by the Ministry of the Environment. Drinking Water Surveillance Program sampling is analyzed by the Ministry of the Environments central laboratory.

For the purpose of this report our system supplies water for a population of 2,106. The number of households connected to our system is 1,292. Households are deemed to include residential, multiple unit residential, institutional and industrial locations.

## **2.0 MANITOUWADGE WATER WORKS**

### **2.1 WATER SOURCE**

Have you ever really thought about where your water comes from?

Contrary to majority public opinion, our water comes from five drilled wells and not from Manitouwadge Lake. This community is blessed with an ample supply of water from an enormous aquifer located deep under the town site bounded by hills surrounding the valley where we are situated.

Water quality does not change quickly due to the depth and the size of our aquifer. The water temperature varies from 7 °C to 8.7 °C year round. Like most drilled wells, our water is extremely hard and slightly aggressive. Allowing the well water to pass through induced draught aerators, the naturally occurring hydrogen sulfides is scrubbed off, yielding a fairly consistent pH in the 7.6 to 7.9 range.

The natural colour of our water is extremely clear and its turbidity is very low. Hence, the addition of a 12% sodium hypochlorite solution used for disinfection produces extremely low levels of trihalomethanes (THMs).

### **2.2 HISTORY**

The Manitouwadge Distribution System was first constructed in 1954 and has gone through several upgrades since.

Initially, there was one drilled well that pumped directly into the water main with no treatment. Pressure and flow were controlled by a pressure reducing valve powered by a 50 horsepower motor. It was coupled to a four cylinder engine on a right angle drive to provide water during power outages. The system was not automatic, necessitating a workman to come to start the engine, engage the drive and disengage and stop the engine



before restoring it to main power. Capacity was 30.2 L/sec (400 IGPM). Increased demand necessitated a second drilled well. Capacity increased to 60.4 L/sec (800 IGPM). Duty was divided between these two pumps. A prolonged decrease in pressure would signal the second pump to run, meeting flow and pressure demands.

In 1962, numerous water breaks revealed that our water was corroding our water mains. The solution was to construct an induced draught aerator to raise the pH of the water. This necessitated the construction of an in-ground storage tank of 55 cubic meters (12,000 IG) to receive the aerated water. Two high lift service pumps pumped the water into the water mains controlled by pressure reducing valves. The motors on the existing well pumps were reduced to 25 horsepower. The high service pumps were 50 horsepower each. One of the high service pumps was coupled to a six cylinder engine on a right angle drive. It was later upgraded to automatic operation during a power outage. However, should the reservoir run low on water, the stand-by well motor will have to be run manually.

The town continued to grow. The wells and reservoir could no longer maintain normal daily flows, forget fire flows. In 1975, a second in-ground reservoir, of 59 cubic meters (13,000 IG) capacity, was added. An additional induced draught aerator was supplied to handle the two new drilled wells, located adjacent to the Lion's Beach. A ten inch raw water main was constructed to supply the reservoirs located at the Shawinigan Place distribution centre. A 100 KW Diesel generator was installed to provide emergency power for well pumps #3 and #4. Emergency well capacity increased from 30.2 L/s (400 IGPM) to 120.6 L/sec (1,200 IGPM). A fifth drilled well was later added, in 1989. An upgrade to the sewage lift station, in 1984, saw the upgrading of diesel generator to 200 KW. However, this resulted in the emergency well pumping capacity dropping to 60.4 L/sec (800 IGPM).

Two additional high service pumps were added to bring our firm pumping capacity to 120.8 L/sec (1,600 IGPM). One of these pumps was connected to a motor driven right angle drive, boosting our emergency pumping capacity to 60.4 L/sec (800 IGPM).

By 1984, the inadequacy of our water supply became apparent. Consistent failure of the emergency pumping systems, and the age of the equipment and its operating systems, prompted a detailed study.

The Hemlo Gold find prompted the final 1990 expansion of our water distribution system. A 4,065 cubic meter (893, 000 IG) two-celled reservoir was constructed. Two dedicated fire pumps were added and the existing high service pumps were upgraded to 40.5 L/sec (525 IGPM). Firm pumping capacity was increased to 243 L/sec (3,200 IGPM).

A 400 KW generator was installed to provide emergency power for the entire Shawinigan Place facility. However, our assured well pumping capacity is only 60.4 L/sec (800 IGPM).

In the spring of 2004 the oil lubricated vertical turbines for Well Pumps #1, #2, #3 and #4 were replaced with submersible water lubricated units. The reasons for the upgrade were prompted by Ministry of the Environment Inspectors preference for water lubricated units to eliminate the need for oil. The oil used was of food grade quality; therefore meaning that there was no risk to human health should the well pump break suction. The decision was made on operational basis determined by the relative ease of servicing locally rather than contracting out maintenance services to a specialist well contractor.

Our Facilities can service the peak pumping hours, plus fire flows, for a population of 6,000 people.

As of May 10<sup>th</sup>, 2007 a secondary source of treatment was implemented for the Town Of Manitowadge consisting of 3 UV reactors which were installed in the pumping stations. The UV reactors are posing as an initial treatment used to inactivate pathogens using 254 nm spectrum of light before receiving a secondary treatment of disinfection as stated above. These reactors are designed to achieve maximum inactivation at a minimum dosage rate of 42 mJ/cm<sup>2</sup>. This dosage rate will supply sufficient inactivation to specific micro organisms passing through the light spectrum. Inactivation consists of a physical process which fuses the DNA of the microorganism rendering it incapable of replication.

Over the past three years Jon Nelson of Nelson Technical Services has been implementing a change in method of which the control of the water plant is conducted. As of the end of 2011 the water treatment plant is now controlled using SCADA (Supervisory Control And Data Acquisition) System. The SCADA System is a visual control system which allows operators to see changes made to the processes in real time. The SCADA system has various pages for viewing which include System overview, Service pumps, Well pumps, System settings, and Alarm History, Analog Inputs, and pump hour meters.

The System Overview is exactly that, an overview of all the service pumps, well pumps, reservoir and UV system and what is running in real time. The Service pump page indicates what service pump is supplying the distribution system as well this page allows you to select service pumps and run them manually. The well pump page indicates which well pump is selected, and allows operators to run well pumps manually. System settings page is where all the settings are located and allows operators to view and change set points for the reservoir, Selection for lead service pumps and lead well pumps. Also the system settings page allows operators to view alarm set points. Alarm History page is just accumulation of alarms that have previously happened. (i.e. Pump Failure or UV Failure). The Analog page is a visual indication of all the input readouts. (i.e. CL2, Turbidity, Temp, etc.). Pump hour meter page allows operators to visually see how many hours are on each pump indicates to operators which pump need to be ran to have even runtime and distribute the everyday wear and tear on the pumps. In the near future Jon Nelson will commission the Daily Reporting page which will allow operators to print out daily reports on a regular basis.

The SCADA System also has trending pages which allow operators to visually look at graphs and see anomalies in the data, whether it be in five minute intervals up to weekly or monthly intervals. This feature is good as you can pinpoint the timeframe then go back to the actual data and identify the numbers associated with the anomalies.

During the fall of 2013 we had a catastrophic failure of the 200 KW generator that supplies emergency power to well 3, 4 pumping station along with the sewage lift station facility. The 200 KW generator was replaced with a 300 KW unit to allow for greater capacity in emergency situations. A building was constructed in the lift station compound and the new generator relocated.

During the fall of 2013 Lotowater Technical Services Inc. was hired to complete a service program at well #1 and #5. Work involved the chemical rehabilitation of Well #1 screen and mechanical rehabilitation #5 screen to increase recovery rates. Well #1 pump was replaced and original equipment sent out for service to be used as replacement equipment. Well #5 oil lubricated line shaft pump was also replaced with a submersible pump.

### **2.3 OPERATIONS**

System pressure controls the operation of six (6) high power pumps. The lead pump is controlled by a variable frequency driver. The VFD increases the lead pump's speed to maintain system pressure until the maximum motor speed is reached. As demand increases and as the system pressure drops to and remains 2.5 to 5.0 PSI below the system pressure set point (currently 80 PSI) for twenty (20) seconds, a second high service pump is called at constant (maximum speed, and then starts following a five (5) second time delay. The lead pump's speed is adjusted by the VFD to compensate and maintain the system pressure at its set point.

As system demand increases further, the lead pumps speed increases to maximum, and when the system pressure set point drops 2.5 to 5 PSI for a twenty (20) second period, a second high service pump at constant speed is called and then starts after a five (5) second time delay.

### **2.4 DECREASING DEMAND**

The lead pump decreases its speed via the VFD to maintain system pressure until the minimum speed is attained. As demand decreases and the system pressure rises and remains 2.5 to 5 PSI above the set point for a period of ten (10) seconds, a high service pump at a constant speed is stopped. The VFD adjusts the lead pumps to compensate and maintain the system pressure set point.

## **2.5 WELL PUMPS**

Reservoir levels control the operation of five (5) well pumps. When the reservoir level falls to the start level for duty one, the pump assigned to duty one will start and continue to run until the reservoir level rises to the stop level programmed for the duty one. In a similar manner, their remaining pumps will start or stop in accordance with their programmed start and stop levels when reached according to the well pump duty cycle for duties two (2) to five (5).

Up until the end of 2011 well pump Flow (Q) was controlled by throttling valves to achieve the desired flow on the flow meter. As of the end of December 2011 Automation Now and Nelson Technical Services installed five 25 hp VFD's on each of the well pumps, which allowed us to open up the valves and control the speed of the pump using the VFD's to achieve the desired flow on the flow meters. The addition of the VFD control benefits the plant in a variety of ways, not only is the wear and tear on the pumps valves and piping minimized but we are also running the well pumps more efficiently. The installation of the VFD's on the well pumps boasted approximately a 45 % reduction in energy usage just by controlling the speed of the pump rather than throttling the valves.

## **2.6 PUMP SETUP**

Within the system, there were two (2) variable frequency drivers, six (6) high service lift pumps and five (5) well pumps. As of the end of December Automation Now and Nelson Technical Services installed an additional two (2) VFD's on the service pumps which supply the town's water through the distribution system. The operator now selects which pump is the going to be the lead pump with the option of selection two service pumps as the lead pumps. After pump selection is achieved automatically the VFD that is hooked up to that service pump will run to maintain the desired pressure in the distribution system. Lead pumps are cycled to achieve an equal run time.

The operator selects from service pumps 1 to 4 the lead pump. High service pumps #5 and #6 can never be selected as lead pumps. Pump # 5 becomes the automatic selection when you select service pump #1 or #2 and Pump #6 becomes the automatic selection when service pump #3 or #4 is selected. Also another feature that was put in place is if the power fails and the PLC dumps and we loose control a service pump will run on minimum speed to insure that the pressure in the distribution system doesn't drop until we can get the PLC repaired.

The operator selects from well pumps 1 to 5 the lead well pump. The balance of the pumps becomes duties 2 to 5. As with the VFD's and the high service pumps, care is taken to run each well pump on a regular basis to equally distribute the wear and tear of the regular operations.

### **3.0 WATER QUALITY**

Some parameters may be present in source water before we treat it. Here is description of the various groups of parameters.

Microbiological Parameters, such as bacteria, may come from sewage plants, livestock operations, septic systems and wildlife. Microbiological quality is the most important aspect of the drinking water quality because of its association with dangerous water-borne disease which can strike quickly.

Inorganic Parameters, such as salts and metals, can be naturally occurring, or a result of urban storm runoff, industrial or domestic wastewater discharge, mining or agriculture. Some may be a result of treatment and distribution of water (for example, lead from old solder in pipes).

Organic Parameters can be naturally occurring, but most organics of concern are synthetic. They originate from industrial discharges, urban storm runoff and other sources. Included in this group are pesticides that originate from both, rural and urban areas. Some may originate from treatment of drinking water (for example, chlorination byproducts such as trihalomethanes).

### **4.0 SOME WATER FACTS**

#### **4.1 DATA**

See Appendix A for the relevant flow data.

Appendix A-1 shows the sodium hypochlorite and chlorine usage and the average daily dosage rate.

Appendix A-2 summarizes the total monthly flows juxtaposed with the average, minimum and maximum for actual flows and peak daily flows.

Appendix A-3 features a summary of the minimum and maximum daily flows on a monthly basis highlighting the day that they occurred.

Appendix A-4 in accordance with our Certificate Of Approval features a summary of the minimum and the maximum daily flows on a monthly basis also highlighting the day that they occurred. Please note that these flows are calculated using the peak flow for that day extrapolated to a daily flow. They are not actual daily flows.

Appendix A-5 shows an annual overview of the actual daily flows.

Appendix A-6 is an annual summary of maximum instantaneous daily flows.



Appendix A-7 annually summarizes the minimum instantaneous daily flows.

Our Treatment Plant delivered 325,271,000 liters of potable water to its consumers 6,051 liters of 12% sodium hypochlorite solution yielding 848.11 kilograms of chlorine used for disinfection purposes. This translates to an annual dosage rate of 2.66 mg/L.

On a per capita basis this translated to 423 liters per person per day. Based on the 2012 figure of 394 liters per person per day this represents a 7.4 % increase in water consumption per person per day.

On a household basis this means that 689 liters per household per day were consumed. Based on the 2012 figure of 642 liters per household per day, this represents a 7.3 % increase in consumption levels.

## 4.2 Water Metering

Completion of the water meter installations in April 2005 prompted the creation of Figure 4.2. It shows the percentage decrease in water consumption commensurate with the billing for the water usage.

Fig 4.2					
Month	2012		2013		Reduction
	Total Flow m <sup>3</sup>	Average Daily Flow m <sup>3</sup>	Total Flow m <sup>3</sup>	Average Daily Flow m <sup>3</sup>	
January	30137	969.48	30807	993.80	2.22
February	29730	1026.46	28813	1029.06	-3.08
March	27026	869.32	33582	1083.30	24.26
April	25312	839.03	33375	1112.50	31.85
May	28643	919	31958	1030.91	11.57
June	32100	1062.57	26711	890.40	-16.79
July	28712	922.13	29372	947.49	2.30
August	23567	759.06	27124	874.97	15.09
September	19856	657.43	21581	719.37	8.69
October	18354	592.06	18713	603.66	1.96
November	17736	632.7	19882	662.74	1.12
December	21800	701.35	23349	753.21	7.10
<b>Total/Average</b>	<b>302973</b>	<b>829.22</b>	<b>325271</b>	<b>891.15</b>	<b>7.19</b>

\*\*\* When there is a (-) % that is actually a decrease from previous year and when there is no (-) sign that indicates an increase from the previous year. Even though there were increases in some months the overall reduction is based on the annual comparison.

## **5.0 COMPLIANCE ISSUES**

### **5.1 SAMPLING**

Appendix B-1 gives a summary of the laboratory analysis for Ontario Regulation 170/03 annual sampling requirements for inorganics. There was one exceedence.

Appendix B-2 gives a summary of the laboratory analysis for Ontario Regulation 170/03 annual sampling requirements for organics. There were no exceedences.

Appendix B-3 gives a summary of the laboratory analysis for Ontario Regulation 170/03 quarterly sampling requirements for organics. There were no exceedences.

Appendix B-4 and B-5 gives a summary of the laboratory analysis performed under the auspices of the Ontario Drinking Water Surveillance Program. B4-a and B4-b deal with various chemical, physical and operational parameters. B4-deals specifically with raw water and B4-b deals with treated water. There was one exceedence for Hardness. Please pay close attention to the footnotes provided.

B5-a and B5-b deal with various inorganic parameters. B5-a deals specifically with raw water and B5-b deals with treated water. There were some exceedences. Please pay careful attention to the footnotes.

Appendix C-1 details a summary of our weekly raw water bacteriological sampling requirements under Ontario Regulation 170/03. There were no exceedences.

Appendix C-2 details a summary of our weekly treated water bacteriological sampling requirements under Ontario Regulation 170/03. There were no exceedences.

Appendix C-3 summarizes our weekly bacteriological sampling requirements for the distribution system under Ontario Regulation 170/03. There were no exceedences.

### **5.2 Peak Flows**

Under our Certificate of Approval we are required to monitor our instantaneous maximum daily flow and translate this into a daily flow also known as a "Peak Flow". This figure should not exceed our Maximum Allowable Daily Flow of 10, 472 m<sup>3</sup>/day. Any flows in excess of this must be documented together with a reason for the exceedence.

For 2013 there were Three (3) such exceedences. Figure 5.2 represents this exceedence with a brief explanation for the occurrence.

**Figure 5.2**

<b>Peak Flow Exceedences</b>		
<b>Day/Date</b>	<b>Flow (m<sup>3</sup>/day)</b>	<b>Probable Causes</b>
<b>Monday, July 15<sup>th</sup>, 2013</b>	10,593.50	OCWA Annual Watermain Swabbing
<b>Tuesday, Aug 27<sup>th</sup>, 2013</b>	10,964.16	Hydrant Flushing
<b>Tuesday, Sept 03<sup>th</sup>, 2013</b>	21,600.00	Erroneous Reading due to Meter Calibration

## **6.0 CERTIFICATE OF APPROVAL**

### **6.1 DAILY LABORATORY TESTING AND OPERATIONAL PARAMETERS**

Appendix D-1 summarizes our Certificate of Approval mandated daily in-house laboratory testing for various operational parameters and distribution system zone sampling. To address a request by the Ministry Of Environment Inspector that our results mirror the M.O.E. form III reporting this appendix goes from 1a to 1g. Included in these results as requested by the M.O.E. are the Raw Well Turbidity readings which are analyzed for once a month and recorded in a spread sheet.

Appendix D-2 summarizes our Certificate of Approval mandated On-Line Instrumentation As per M.O.E. request to mirror form III reporting this appendix goes from 2a to 2d. There were no exceedences.

Our On-Line instrumentation and our Laboratory analyzers were re-calibrated by Andre Lemoine who is a Clear Tech technician on July 13<sup>th</sup>, 2013.

### **6.2 FLOW METERING**

Our Certificate of Approval mandates that our flow meters must be accurate within plus or minus five (5%) percent of the raw water and treated water flow meters.

Appendices E1 to E13 sets out the accumulated data for January through December. Appendix E1 is a summary of the monthly totals of Appendices E2 to E13. This shows that for the period represented by this data that is an average we were in compliance.

However, as you pursue this data you may notice that some daily and some monthly figures seem to be out of compliance. The explanation for this is as follows: The well flow meters are the most accurate and these flows are used to compute the daily flows. Each well is restricted to 30.3 liters per second and the corresponding meter is set accordingly. The raw water flow meter to achieve the maximum accuracy is programmed to accurately measure flows up to 91.2 liters per second which represents the combined flow of three wells. When more than three wells are running such as during hot days or major water break or fire hydrant usage the accuracy falls off.



Similarly the treated water meter is programmed to be accurate with flows not exceeding 120 liters per second. This represents the maximum flow at 80 psi that three of our six high service pumps can produce. During high flow conditions such as hot weather demand, major water breaks or fire hydrant usage when more than three high service pumps are required the accuracy again falls off.

Please realize that the accuracy of the flow metering equipment is monitored on a daily basis by our operations personnel. The well flow meter and hour meter, raw water meter and treated water meter are read daily. Hour meter readings are subtracted from the previous days reading and multiplied by the well meter flow usual 108 cubic meters per day and compared with difference in the flow meter reading to ensure that it is within plus or minus five percent of each other. The results of the five wells are then added and then compared with the differences for the raw water and treated water flow meters.

Our flow meters were re-calibrated by Endress + Hauser on September 03, 2013.

### **6.3 LEAD SAMPLING PROGRAM**

In spring 2008 M.O.E mandated that lead sampling be conducted in accordance with OR 170-03 Community Lead sampling. Lead Sampling was to commence twice annually during the spring and again in the fall. Due to sample results not exceeding the 10 ug/L limit the Township of Manitowadge will be exempt from lead sampling for a duration of 3 years. The lead sampling program will recommence in 2016.


### **6.4 UV Treatment Operations & Data**

This section was a result of the installation of the three (3) UV Reactors one for each of the pump houses. The data was averaged out on a monthly basis and the data was input into tabular format as well as a graph was plotted to show the average monthly comparison of each of the reactors. See below figure 6.4a and 6.4b.

Figure 6.4 a

2013	Well 1 & 2 Average Dosage mJ/cm <sup>2</sup>	Well 3 & 4 Average Dosage mJ/cm <sup>2</sup>	Well 5 Average Dosage mJ/cm <sup>2</sup>
January	145	64	41
February	107	70	86
March	79	83	84
April	80	133	57
May	99	118	57
June	116	74	64
July	76	112	64
August	92	10	71
September	70	12	129
October	69	6	124
November	64	163	121
December	69	221	88
<b>Average</b>	<b>89</b>	<b>89</b>	<b>82</b>

Figure 6.4 b



\*\*Average dosage reading was calculated based on all the data provided. This means that even when the unit wasn't running it was logging a zero reading. Therefore the dosages that yielded a low average result is a result of all the zeros in the calculation as well as the frequency of well run time. Run time increases when the well is selected by the lead pump.

## **7.0 MINISTRY ORDERS**

1. Review of the 2012 M.O.E Drinking water Inspection report revealed that no orders were issued.

## **8.0 CONCLUSION**

The Township had an extremely busy 2013.

1. The Township had contracted out to the Ontario Clean Water Agency (O.C.W.A.) the third of a three year swabbing plan. O.C.W.A. in accordance with the Township of Manitowadge swabbed pipes in Zone #3 which was completed over a three day process which consisted of 39.5 regular man hours and 5 overtime man hours.
2. During the Swabbing program Water Operators also conducted the valve exercising program which insured smooth operation during the swabbing program. The valve exercising program allowed operators to identify and repair deficiencies in the distribution system.
3. During the fall of 2013 Lotowater Technical Services Inc. was hired to complete a service program at well #1 and #5.
  - a. On September 17, 2013 a single rate well performance test was completed on Well #1. The performance test indicated that Well #1 was currently at 10% of the as-constructed level. A pre-rehabilitation video was then completed which indicated severe biological fouling of the well screen. The rehabilitation of Well #1 involved brushing, surging and air lifting followed by the treatment of an acid polymer solution and finally air lifting of the well until clear water was being produced. The pump and motor was then replaced and the original equipment was sent to be service to be used as replacement equipment. On September 20, 2013 the well performance test was once again conducted. The results showed performance is currently above as constructed levels.
  - b. On September 19, 2013 a single rate well performance test was completed on Well #5. The performance test indicated that Well #5 performance has not changed significantly since construction. A pre-rehabilitation video was then completed which indicated severe biological fouling of the well screen. The rehabilitation of Well #5 involved the mechanical cleaning of the well screen and the video completed prior to cleaning indicated successful removal of fouling from the well screen. Well #5 oil lubricated line shaft pump was then replaced with a submersible pump.

4. As assessment of the main distribution pump house roof located at Shawinigan Place Holmes Roofing and Sheet Metal indicated that a complete resurfacing was required. Work commenced on October 30, 2013 and completed on November 12, 2013. Holmes Roofing is to return in 2014 to complete the flashing on the pump house roof.
5. During the fall of 2013 we had a catastrophic failure of the 200 KW generator that supplies emergency power to well 3, 4 pumping station along with the sewage lift station facility. Due to age the 200 KW generator it was deemed unrepairable. The 200 KW generator was replaced with a 300 KW mobile unit supplied by GAL Power. This would now allow for greater pumping capacity in emergency situations. The previous generator location was not suitable for the 300 KW and a new building was constructed in the lift station compound and the new generator relocated.
6. The Township public works department spent 411.5 regular man hours, 32.5 overtime hours and 3.5 double time hours on water service repairs.
7. The Township public works department spent 289.5 regular man hours, 67.5 overtime hours and 1 double time hour on water main repairs.
8. The Township public works department spent 25 regular man hours on steaming fire hydrants.
9. The Township public works department spent 63 regular man hours and 1.5 overtime hours on water service disconnections.
10. The Township public works department spent 51 regular man hours on water service reconnections.
11. The Township public works department spent 56 regular man hours on water meter repairs.
12. The Township public works department spent 35.5 regular man hours and 0.5 overtime hours on water meter readings
13. The Township public works department spent 36.5 regular man hours and 15 overtime hours on frozen water lines.
14. The Township public works department spent 32 regular man hours and 4 overtime hours on swabbing water mains
15. The Township public works department spent 15.5 regular man hours and 1 overtime hour on valve exercising.

## **RECOMMENDATIONS**

1. Completion of the roof at the main pumphouse.
2. Cleaning of the reservoir.
3. Data acquisition and daily report capabilities from SCADA system.
4. Completion of rehabilitation program on wells 2, 3 and 4.

**ANNUAL REPORT  
2013  
SUMMARY OF  
SODIUM HYPOCHLORITE USAGE**

**Appendix A-1**

Month	12% Sodium Hypochlorite Solution	Chlorine	Dosage Rate
	Liters (L)	Kilograms (kg)	mg/L
January	513	71.83	2.39
February	512	71.69	2.53
March	561	78.56	2.36
April	564	78.98	2.38
May	562	78.70	2.46
June	488	68.40	2.56
July	562	78.77	2.68
August	516	72.25	2.64
September	470	65.88	3.07
October	398	55.71	2.96
November	422	59.08	3.02
December	487	68.26	2.89
<b>ANNUAL</b>	<b>6,051</b>	<b>848.11</b>	<b>2.66</b>

**ANNUAL REPORT  
2013  
SUMMARY OF MONTHLY ACTUAL AND PEAK FLOWS**

**APPENDIX A-2**

Total Flow (m <sup>3</sup> )	Actual Daily Flows (m <sup>3</sup> /Day)			Month	Peak Daily Flows (m <sup>3</sup> /Day)			Exceedence
	Average	Minimum	Maximum		Average	Minimum	Maximum	
30,807.74	993.80	701.85	2,063.93	January	1,212.84	0.00	7,495.20	N
28,813.68	1,029.06	864.41	1,425.07	February	1,137.53	430.27	2,163.46	N
33,582.44	1,083.30	909.16	1,468.36	March	1,205.36	492.48	2,308.61	N
33,375.05	1,112.50	958.50	1,292.86	April	1,347.51	0.00	9,011.52	N
31,958.27	1,030.91	798.59	1,211.21	May	1,182.18	3.46	4,973.18	N
26,711.95	890.40	674.16	1,091.97	June	1,155.43	0.00	6,487.79	N
29,372.19	947.49	724.37	1,830.78	July	1,566.64	0.00	10,593.50	Y
27,124.04	874.97	491.48	1,527.30	August	1,345.66	1.73	10,964.16	Y
21,581.03	719.37	462.32	876.06	September	1,287.92	0.00	21,600.00	Y
18,713.39	603.66	492.33	687.42	October	1,002.37	0.00	7,517.66	N
19,882.17	662.74	519.53	793.79	November	1,002.99	3.46	7,717.25	N
23,349.38	753.21	294.62	1,450.23	December	947.20	16.42	3,961.44	N
325,271.33	891.15	294.62	2,063.93	Annual	1,199.47	0.00	21,600.00	Y

<sup>1</sup> Under our Certificate of Approval our Maximum Allowable Daily flow is 10,472 m<sup>3</sup>/Day. Any time the instantaneous Peak Flow exceeds 10,472 m<sup>3</sup>/Day a note must be made of the circumstances that created the flow.

# ANNUAL REPORT

2013

## SUMMARY OF MONTHLY MAXIMUM AND MINIMUM DAILY PEAK FLOW EVENTS

Appendix A-3

Minimum Daily Flow m <sup>3</sup>	Day	Date	Month	Day	Date	Maximum Daily Flow m <sup>3</sup>
660.98	Tuesday	7th	January	Wednesday	22nd	1,993.65
835.59	Friday	1st	February	Sunday	24th	1,304.44
880.24	Tuesday	12th	March	Sunday	17th	1,461.83
942.61	Monday	15th	April	Saturday	27th	1,253.47
772.38	Thursday	23rd	May	Monday	6th	1,194.89
777.48	Sunday	16th	June	Tuesday	25th	1,022.13
710.54	Sunday	7th	July	Tuesday	16th	1,824.72
625.46	Saturday	31st	August	Sunday	18th	1,503.59
461.88	Sunday	29th	September	Thursday	12th	892.65
462.86	Monday	7th	October	Monday	28th	708.05
523.00	Monday	18th	November	Sunday	10th	839.75
598.41	Friday	13th	December	Wednesday	18th	1,482.03
461.88			Annual			1,993.65



# ANNUAL REPORT

2013

## SUMMARY OF MONTHLY

### MAXIMUM AND MINIMUM INSTANTANEOUS DAILY PEAK FLOW EVENTS

Minimum Daily Flow m <sup>3</sup>	Day	Date	Month	Day	Date	Maximum Daily Flow m <sup>3</sup>
0.00	Friday	18th	January	Thursday	17th	7,495.20
430.27	Friday	1st	February	Saturday	23rd	2,163.46
492.48	Friday	8th	March	Friday	22nd	2,308.61
0.00	Tuesday	30th	April	Thursday	4th	9,011.52
3.46	Monday	13th	May	Thursday	30th	4,973.18
0.00	Thursday	27th	June	Monday	24th	6,487.79
0.00	Monday, Saturday, Monday	8th, 27th, 29th	July	Monday	15th	10,593.50
1.73	Tuesday	13th	August	Tuesday	27th	10,964.16
0.00	Tuesday	3rd	September	Tuesday	3rd	21,600.00
0.00	Friday	4th	October	Wednesday	16th	7,517.66
3.46	Monday	4th	November	Monday	4th	7,717.25
16.42	Saturday	7th	December	Thursday	19th	3,961.44
0.00			Annual			21,600.00

Appendix A-4



Maximum Instantaneous Readings


2013	January	Feb	March	April	May	June	July	August	September	October	November	December
1	Tue 1,805.76	Fri 1,531.01	Fri 1,708.99	Mon 1,786.75	Sat 1,677.89	Mon 1,738.37	Thu 1,799.71	Sun 1,503.36	Tue 1,356.48	Fri 1,351.30	Sun 1,663.20	Sun 1,545.70
2	Wed 1,793.30	Sat 1,592.38	Sat 1,881.79	Thu 1,734.05	Mon 1,705.54	Tue 1,592.35	Fri 1,761.70	Mon 1,590.62	Wed 1,543.97	Sat 1,783.30	Mon 1,601.86	Mon 1,486.08
3	Thu 1,321.92	Sun 1,761.70	Sun 1,805.76	Fri 1,782.19	Tue 1,716.77	Wed 1,567.30	Mon 1,573.23	Tue 1,772.83	Thu 2,160.00	Sun 2,172.10	Tue 1,459.90	Tue 1,620.00
4	Fri 1,309.82	Mon 1,522.37	Mon 1,558.66	Mon 9,011.52	Wed 1,963.61	Thu 1,761.07	Fri 5,735.23	Wed 1,620.00	Mon 1,389.31	Mon 1,478.30	Wed 7,717.25	Wed 1,313.28
5	Sat 1,554.46	Tue 1,518.05	Tue 1,645.05	Fri 2,050.27	Thu 1,939.68	Fri 1,880.06	Mon 1,641.60	Thu 1,538.19	Sat 1,442.02	Tue 1,384.38	Thu 4,553.02	Thu 1,801.44
6	Sun 1,656.29	Wed 1,647.65	Wed 1,645.15	Sat 2,020.03	Mon 1,830.82	Sat 2,128.90	Tue 1,641.60	Mon 1,641.60	Wed 1,505.95	Wed 1,255.39	Mon 1,763.82	Fri 1,583.71
7	Mon 1,365.98	Thu 1,607.04	Thu 1,652.83	Sun 1,928.45	Fri 1,727.14	Mon 1,631.23	Thu 1,448.93	Sat 1,708.99	Thu 1,505.95	Thu 1,512.86	Sun 1,669.12	Sun 1,664.06
8	Tue 1,407.06	Fri 1,529.28	Fri 1,814.40	Mon 1,669.25	Sun 1,918.08	Tue 1,986.46	Mon 1,485.22	Sat 1,596.67	Mon 1,985.47	Mon 1,404.00	Wed 1,480.03	Thu 1,447.20
9	Wed 1,340.06	Sat 1,848.96	Sat 1,918.08	Tue 1,740.10	Mon 1,791.07	Wed 1,986.46	Tue 1,626.91	Mon 1,754.78	Thu 1,985.47	Fri 1,532.86	Thu 1,669.12	Mon 1,669.12
10	Thu 1,910.30	Sun 1,788.48	Sun 1,695.66	Wed 1,934.00	Tue 1,823.90	Thu 1,488.08	Wed 1,336.61	Tue 1,656.29	Mon 1,616.54	Sun 1,507.68	Mon 1,504.40	Wed 1,504.40
11	Fri 1,432.91	Mon 1,572.04	Mon 1,583.77	Thu 1,715.90	Wed 1,911.36	Mon 1,512.86	Thu 1,454.98	Wed 1,656.29	Tue 1,975.96	Fri 1,537.92	Wed 1,467.94	Thu 1,560.38
12	Sat 1,645.92	Tue 1,607.04	Tue 1,665.66	Fri 1,874.02	Thu 1,863.65	Tue 1,672.70	Mon 1,404.00	Thu 1,461.88	Wed 1,683.94	Mon 1,382.40	Thu 1,410.91	Thu 1,558.66
13	Sun 1,618.27	Wed 1,607.04	Wed 1,575.07	Sat 1,874.02	Fri 1,891.79	Sat 4,973.18	Tue 1,492.99	Sat 1,461.88	Thu 1,966.46	Tue 1,507.68	Mon 1,560.38	Fri 1,558.66
14	Mon 1,448.93	Thu 1,656.29	Thu 1,667.52	Mon 1,863.65	Sun 1,889.12	Mon 1,511.14	Wed 10,593.50	Mon 1,461.88	Mon 1,975.96	Wed 1,324.76	Mon 1,410.91	Sat 1,522.37
15	Tue 1,405.73	Fri 1,611.36	Fri 1,994.11	Tue 1,812.67	Mon 1,776.38	Tue 1,549.15	Thu 8,846.50	Tue 1,590.62	Wed 1,756.51	Thu 2,005.34	Mon 1,445.47	Mon 1,491.26
16	Wed 1,460.16	Sat 1,796.26	Sat 1,994.11	Wed 1,812.67	Tue 1,718.50	Wed 1,580.26	Fri 8,913.89	Wed 1,786.75	Thu 1,522.37	Mon 1,634.69	Mon 1,445.47	Mon 1,491.26
17	Thu 7,495.20	Mon 1,745.28	Mon 2,064.96	Thu 1,912.67	Wed 1,878.34	Thu 1,598.40	Sat 8,462.02	Thu 2,050.27	Mon 1,522.37	Tue 1,433.38	Mon 1,445.47	Mon 1,491.26
18	Fri 1,979.42	Tue 1,641.60	Tue 1,834.78	Fri 1,805.76	Thu 1,949.18	Fri 1,567.30	Mon 1,616.54	Mon 1,705.54	Tue 3,879.36	Wed 1,385.86	Mon 1,445.47	Mon 1,491.26
19	Sat 1,636.91	Wed 1,600.13	Wed 1,837.73	Sat 1,805.76	Mon 1,812.67	Sat 1,571.92	Tue 1,511.14	Tue 1,855.87	Wed 1,581.98	Thu 1,503.38	Mon 1,445.47	Mon 1,491.26
20	Sun 1,628.21	Thu 1,600.13	Thu 2,059.78	Sun 1,817.86	Tue 1,924.37	Sun 1,571.92	Wed 1,511.14	Wed 1,620.00	Thu 1,716.77	Fri 1,601.86	Mon 1,445.47	Mon 1,491.26
21	Mon 3,501.79	Fri 1,467.07	Fri 1,834.78	Mon 1,847.23	Wed 1,954.37	Mon 1,745.28	Thu 1,438.56	Thu 1,916.35	Mon 1,512.86	Sat 1,326.24	Mon 1,445.47	Mon 1,491.26
22	Tue 3,510.43	Sat 1,834.27	Sat 2,308.61	Tue 1,807.49	Thu 1,620.00	Tue 4,222.37	Fri 1,661.34	Fri 1,522.37	Tue 2,712.96	Sun 1,326.24	Mon 1,445.47	Mon 1,491.26
23	Wed 2,597.18	Mon 2,163.46	Mon 1,888.70	Wed 1,924.99	Mon 1,620.00	Wed 6,487.79	Sat 1,664.06	Sat 1,624.69	Wed 1,494.72	Mon 1,533.60	Mon 1,445.47	Mon 1,491.26
24	Thu 2,553.98	Tue 1,972.51	Tue 1,703.81	Thu 1,885.25	Tue 1,461.89	Thu 1,810.94	Sun 1,626.91	Mon 1,634.69	Thu 1,494.72	Tue 1,656.29	Mon 1,445.47	Mon 1,491.26
25	Fri 1,888.70	Wed 1,690.85	Wed 1,672.70	Fri 1,740.10	Wed 1,687.39	Fri 1,570.75	Mon 1,576.80	Tue 1,964.16	Mon 1,538.78	Wed 1,372.90	Mon 1,445.47	Mon 1,491.26
26	Sat 1,565.02	Thu 1,836.42	Thu 1,683.94	Sat 1,740.10	Thu 1,661.47	Sat 1,570.75	Tue 1,837.73	Wed 1,453.25	Mon 1,531.01	Thu 1,321.92	Mon 1,445.47	Mon 1,491.26
27	Sun 1,590.62	Wed 1,683.94	Wed 1,616.54	Mon 2,032.99	Mon 1,661.47	Sun 1,460.16	Wed 1,690.85	Thu 1,509.41	Tue 1,422.14	Fri 1,435.10	Mon 1,445.47	Mon 1,491.26
28	Mon 1,498.18	Thu 1,708.99	Thu 1,829.09	Tue 1,988.93	Tue 1,759.97	Mon 1,616.54	Thu 1,690.85	Mon 1,509.41	Wed 1,422.14	Sat 1,321.92	Mon 1,445.47	Mon 1,491.26
29	Tue 1,489.54	Fri 1,708.99	Fri 1,863.65	Wed 1,841.18	Wed 1,592.35	Tue 1,750.46	Mon 1,690.85	Tue 1,343.52	Thu 1,351.3	Sun 1,321.92	Mon 1,445.47	Mon 1,491.26
30	Wed 1,620.00	Sat 1,901.66	Sat 1,901.66	Thu 1,841.18	Thu 1,592.35	Wed 1,750.46	Tue 1,690.85	Mon 1,343.52	Mon 1,351.3	Mon 1,360.80	Mon 1,445.47	Mon 1,491.26
31	Thu 1,603.58	Mon 1,901.66	Mon 1,901.66	Fri 1,841.18	Fri 1,592.35	Thu 1,750.46	Wed 1,690.85	Mon 1,343.52	Mon 1,351.3	Tue 1,360.80	Mon 1,445.47	Mon 1,491.26

Min	1,308.82	1,467.07	1,525.82	1,588.90	1,438.58	1,460.16	1,336.61	1,343.52	1,351.30	1,255.39	1,231.20	1,035.94
Max	7,495.20	2,163.46	2,308.61	9,011.52	4,973.18	4,973.18	10,593.50	10,984.16	21,600.00	7,517.66	7,717.25	3,961.44
Average	1,956.57	1,887.39	1,785.79	2,074.41	1,848.74	2,009.78	2,727.82	2,317.28	2,363.13	1,956.41	1,900.28	1,615.26


1212.84	1137.53	1205.38	1347.51	1182.18	1155.43	1566.64	1345.66	1287.92	1002.37	1002.99	947.20
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	--------



### Annual Performance Report



### Annual Performance Report



Minimum Instantaneous Readings

2013	January	Feb	March	April	May	June	July	August	September	October	November	December
1	Tue 349.06	Fri 430.27	Fri 561.84	Mon 644.54	Sat 667.01	Mon 364.61	Thu 268.70	Sun 372.98	Tue 25.06	Fri 3.46	Sun 216.00	Sun 216.00
2	Wed 392.26	Sat 497.66	Sat 559.01	Tue 664.42	Sun 686.88	Tue 328.32	Fri 330.91	Mon 328.32	Wed 230.69	Sat 5.18	Sat 26.79	Mon 235.87
3	Thu 227.23	Sun 517.54	Sun 575.42	Fri 649.73	Mon 646.27	Wed 227.23	Sat 456.19	Tue 387.07	Thu 0.00	1.73	Mon 230.69	Tue 235.87
4	Fri 222.05	Mon 552.10	Mon 583.20	Sat 3.46	Tue 672.19	Thu 395.71	Sun 303.26	Wed 468.29	Fri 278.21	0.00	Sat 3.46	Wed 212.54
5	Sat 301.54	Tue 581.47	Tue 609.98	Mon 628.13	Wed 731.81	Fri 435.46	Mon 47.52	Thu 350.78	Sat 286.85	3.46	Fri 6.91	Thu 308.45
6	Sun 387.07	Wed 578.02	Wed 575.59	Tue 641.09	Thu 731.81	Sat 314.50	Tue 14.69	Fri 463.10	Sun 288.58	1.73	Sun 196.13	Fri 204.77
7	Mon 245.38	Thu 510.62	Thu 542.48	Wed 679.10	Fri 673.92	Mon 248.83	Wed 298.08	Sat 390.53	Mon 210.87	1.73	Mon 14.69	Sat 252.29
8	Tue 413.86	Fri 539.14	Fri 492.48	Thu 662.69	Sat 685.15	Tue 317.95	Thu 0.00	Sun 481.25	Tue 210.87	1.73	Tue 210.87	Sun 270.43
9	Wed 350.78	Sat 597.89	Sat 527.04	Fri 695.52	Mon 616.03	Wed 444.96	Mon 270.43	Fri 425.89	Wed 290.30	8.64	Wed 23.33	Mon 270.43
10	Thu 235.87	Sun 595.30	Sun 540.86	Tue 670.46	Tue 603.07	Thu 304.99	Tue 36.29	Thu 387.07	Thu 304.99	6.91	Thu 248.83	Tue 290.30
11	Fri 268.70	Mon 595.30	Mon 570.24	Wed 666.14	Wed 668.74	Fri 290.30	Wed 220.19	Sun 488.16	Fri 332.64	6.91	Fri 374.11	Wed 281.66
12	Sat 373.82	Tue 601.34	Tue 595.30	Thu 648.00	Thu 688.61	Sat 323.14	Thu 222.05	Mon 347.33	Sat 446.69	19.87	Sun 192.67	Thu 278.21
13	Sun 385.00	Wed 583.20	Wed 578.02	Mon 617.76	Fri 664.42	Mon 3.46	Mon 303.26	Tue 1.73	Sun 1.73	6.91	Mon 275.62	Fri 245.38
14	Mon 248.83	Thu 635.90	Thu 566.66	Tue 617.76	Sat 664.42	Tue 292.03	Tue 304.99	Wed 310.18	Mon 316.22	6.91	Mon 6.91	Sat 21.60
15	Tue 550.37	Fri 577.15	Fri 738.72	Wed 635.90	Sun 611.71	Wed 216.00	Wed 3.46	Thu 110.59	Tue 271.30	5.18	Tue 12.96	Mon 260.06
16	Wed 328.32	Sat 573.70	Sat 939.17	Thu 666.14	Mon 611.71	Thu 317.95	Thu 3.46	Mon 432.00	Wed 263.52	3.46	Wed 14.69	Tue 260.06
17	Thu 388.80	Sun 621.22	Sun 962.50	Fri 619.49	Tue 599.62	Fri 365.47	Tue 1.73	Tue 400.03	Thu 293.76	8.64	Thu 330.91	Wed 988.42
18	Fri 0.00	Mon 543.46	Mon 827.71	Sat 670.46	Wed 599.62	Sat 419.90	Wed 316.22	Wed 711.94	Fri 299.81	8.64	Fri 9.50	Thu 278.21
19	Sat 581.47	Tue 588.38	Tue 599.62	Mon 660.96	Thu 668.74	Mon 382.62	Thu 3.46	Thu 400.03	Sat 365.47	5.18	Sat 9.50	Fri 246.46
20	Sun 581.47	Wed 588.38	Wed 599.62	Tue 649.73	Fri 723.17	Tue 306.72	Fri 395.72	Mon 425.09	Sun 290.30	6.91	Sun 15.69	Sat 260.06
21	Mon 659.23	Thu 550.37	Thu 617.76	Wed 675.65	Sat 230.69	Wed 726.62	Mon 308.45	Tue 497.66	Mon 317.59	8.64	Mon 9.50	Sun 349.06
22	Tue 1,022.11	Fri 492.48	Fri 617.76	Thu 713.66	Sun 225.50	Thu 1.73	Tue 387.07	Wed 323.14	Tue 234.14	6.91	Tue 14.69	Mon 312.77
23	Wed 1,416.96	Sat 757.73	Sat 588.38	Fri 718.85	Mon 266.98	Wed 62.20	Wed 381.02	Thu 332.41	Wed 241.92	5.18	Wed 240.19	Tue 312.77
24	Thu 880.42	Sun 616.03	Sun 616.03	Sat 705.02	Tue 266.98	Thu 367.20	Thu 279.94	Thu 332.64	Thu 306.72	5.18	Thu 199.58	Wed 317.82
25	Fri 481.25	Mon 634.18	Mon 599.62	Sun 705.02	Wed 32.83	Fri 62.20	Fri 330.91	Fri 306.72	Fri 5.18	5.18	Fri 222.05	Thu 311.04
26	Sat 494.21	Tue 597.89	Tue 659.23	Mon 695.52	Thu 281.66	Sat 0.00	Sat 330.91	Sat 3.46	Sat 5.18	1.73	Sat 9.50	Mon 283.39
27	Sun 439.78	Wed 611.71	Wed 641.09	Tue 666.14	Mon 223.78	Sun 0.00	Mon 4,899.02	Sun 260.06	Sun 5.18	3.46	Sun 216.00	Tue 328.32
28	Mon 439.78	Thu 591.84	Thu 603.07	Wed 730.08	Tue 532.22	Mon 283.34	Tue 444.96	Mon 204.77	Mon 5.18	268.70	Mon 216.00	Wed 349.06
29	Tue 522.72	Fri 619.49	Fri 613.44	Thu 753.41	Wed 532.22	Tue 375.84	Wed 444.96	Tue 252.29	Tue 3.46	294.62	Tue 216.00	Thu 334.37
30	Wed 532.22	Sat 670.46	Sat 670.46	Fri 0.00	Thu 362.88	Wed 375.84	Thu 0.00	Wed 192.67	Wed 3.46	294.62	Wed 216.00	Mon 334.37
31	Thu 426.82	Sun 670.46	Sun 670.46	Mon 0.00	Fri 362.88	Thu 375.84	Mon 0.00	Thu 192.67	Thu 3.46	294.62	Thu 216.00	Tue 334.37

Min	0.00	430.27	492.48	0.00	3.46	0.00	0.00	1.73	0.00	0.00	3.46	16.42
Max	1,416.96	757.73	962.50	753.41	737.81	726.62	4,898.02	711.94	446.69	294.62	374.11	988.42
Average	456.37	577.68	630.13	620.61	501.43	301.07	358.93	338.21	212.71	37.07	105.70	286.81

Appendix A-7

# ANNUAL REPORT 2013

## Ontario Regulation Annual Sampling Requirement

### Appendix B-1

Summary of Inorganics Treated Water						
Parameter	M.A.C. or I.M.A.C.	Unit of Measure	Result	Unit of Measure	Exceedence	Action Required
Antimony	0.0001	mg/L	< 0.6	ug/L	No	No
Arsenic	0.025	mg/L	< 1	ug/L	No	No
Barium	1	mg/L	43	ug/L	No	No
Boron	5	mg/L	< 500	ug/L	No	No
Cadmium	0.005	mg/L	< 0.1	ug/L	No	No
Chromium	0.05	mg/L	< 1	ug/L	No	No
Flouride	1.5	mg/L	---	mg/L	No	No
Lead	0.01	mg/L	---	ug/L	No	No
Mercury	0.001	mg/L	< 0.1	ug/L	No	No
Nirtate	10	mg/L	1.54	mg/L	No	No
Nitrite	1	mg/L	< 0.02	mg/L	No	No
Selenium	0.01	mg/L	< 1	ug/L	No	No
Sodium <sup>1</sup>	20	mg/L	---	mg/L	Yes	Yes
Uranium	0.1	mg/L	< 2	ug/L	No	No

<sup>1</sup>The Ontario Spills Action Center and the Thunder Bay District Health Unit, Medical Officer of Health have been notified. Warning notices have been posted and local doctors advised to alert persons on a sodium restricted diet to use an alternative potable water supply for cooking and drinking purposes. When sodium levels exceed 200 ug/L, corrective measures may be ordered.

**ANNUAL REPORT  
2013  
Ontario Regulation Annual Sampling Requirement**

Appendix B-2

Summary of Organics Treated Water						
Parameter	M.A.C. or I.M.A.C.	Units	Results	Exceedence	Action Required	
Alachlor	0.005	mg/L	< 0.1 ug/L	No	No	
Aldicarb	0.009	mg/L	< 1 ug/L	No	No	
Aldrin + Dieldrin	0.007	mg/L	< 0.04 ug/L	No	No	
Atrazine + N-dialkylated metabolites	0.005	mg/L	< 0.2 ug/L	No	No	
Azinphos-methyl	0.02	mg/L	< 0.1 ug/L	No	No	
Bendiocarb	0.04	mg/L	< 0.2 ug/L	No	No	
Benzene	0.005	mg/L	< 0.5 ug/L	No	No	
Benzo (a) pyrene	0.0001	mg/L	< 0.01 ug/L	No	No	
Bromoxynil	0.005	mg/L	< 0.2 ug/L	No	No	
Carbaryl	0.09	mg/L	< 0.2 ug/L	No	No	
Carbofuran	0.09	mg/L	< 0.2 ug/L	No	No	
Carbon Tetrachloride	0.005	mg/L	< 0.5 ug/L	No	No	
Chlordane (Total)	0.007	mg/L	< 0.3 ng/L	No	No	
Chlorpyrifos	0.08	mg/L	< 0.1 ug/L	No	No	
Cyanazine	0.01	mg/L	< 0.1 ug/L	No	No	
Diazinon	0.02	mg/L	< 0.1 ug/L	No	No	
Dicamba	0.12	mg/L	< 0.2 ug/L	No	No	
1,2-Dichlorobenzene	0.2	mg/L	< 0.5 ug/L	No	No	
1,4-Dichlorobenzene	0.005	mg/L	< 0.5 ug/L	No	No	
Dichlorodiphenyltrichloroethane (DDT) + metabolites	0.03	mg/L	< 0.4 ng/L	No	No	
1,2-Dichloroethane	0.005	mg/L	< 0.5 ug/L	No	No	
1,1-Dichloroethylene (vinylidene chloride)	0.014	mg/L	< 0.5 ug/L	No	No	
Dichloromethane	0.05	mg/L	< 0.5 ug/L	No	No	
2-4 Dichlorophenol	0.09	mg/L	< 0.3 ug/L	No	No	
2,4-Dichlorophenoxy acetic acid (2,4-D)	0.1	mg/L	< 0.2 ug/L	No	No	
Diclofop-methyl	0.009	mg/L	< 0.2 ug/L	No	No	
Dimethoate	0.02	mg/L	< 0.1 ug/L	No	No	
Dinoseb	0.01	mg/L	< 0.2 ug/L	No	No	
Diquat	0.07	mg/L	< 1 ug/L	No	No	



**ANNUAL REPORT  
2013  
Ontario Regulation Annual Sampling Requirement**

Appendix B-2

Summary of Organics Treated Water						
Parameter	M.A.C. or I.M.A.C.	Units	Results	Exceedence	Action Required	
Diuron	0.15	mg/L	< 1 ug/L	No	No	
Glyphosate	0.28	mg/L	< 5 ug/L	No	No	
Heptachlor + Heptachlor Epoxide	0.003	mg/L	< 0.2 ug/L	No	No	
Linadane (Total)	0.004	mg/L	< 0.1 ug/L	No	No	
Malathion	0.19	mg/L	< 0.1 ug/L	No	No	
Methoxychlor	0.9	mg/L	< 0.1 ug/L	No	No	
Metolachlor	0.05	mg/L	< 0.1 ug/L	No	No	
Metribuzin	0.08	mg/L	< 0.1 ug/L	No	No	
Monochlorobenzene	0.02	mg/L	< 0.5 ug/L	No	No	
Paraquat	0.01	mg/L	< 1 ug/L	No	No	
Parathion	0.05	mg/L	< 0.1 ug/L	No	No	
Pentachlorophenol	0.05	mg/L	< 0.5 ug/L	No	No	
Phorate	0.002	mg/L	< 0.1 ug/L	No	No	
Picloram	0.19	mg/L	< 0.2 ug/L	No	No	
Polychlorinated Biphenyls (PCB)	0.003	mg/L	< 0.035 ug/L	No	No	
Prometryne	0.001	mg/L	< 0.1 ug/L	No	No	
Simazine	0.01	mg/L	< 0.1 ug/L	No	No	
Total Trihalomethanes	0.15	mg/L	30.6 ug/L	No	No	
Temephos	0.28	mg/L	< 0.1 ug/L	No	No	
Terbufos	0.001	mg/L	< 0.2 ug/L	No	No	
Tetrachloroethylene	0.03	mg/L	< 0.5 ug/L	No	No	
2,3,4,6-Tetrachlorophenol	0.1	mg/L	< 0.5 ug/L	No	No	
Triallate	0.23	mg/L	< 0.1 ug/L	No	No	
Trichloroethylene	0.05	mg/L	< 0.5 ug/L	No	No	
2,4,6-Trichlorophenol	0.1	mg/L	< 0.5 ug/L	No	No	
2,4,5-Trichlorophenoxy Acetic Acid (2,4,5-T)	0.28	mg/L	< 0.2 ug/L	No	No	
Trifluralin	0.045	mg/L	< 0.1 ug/L	No	No	
Vinyl Chloride	0.07	mg/L	< 0.5 ug/L	No	No	



# ANNUAL REPORT 2013

## Ontario Regulation Quarterly Sampling Requirement

Appendix B-3

Summary of Inorganics								
Treated Water								
Parameter	M.A.C. or I.M.A.C.	Unit of Measure	January 14	March 01	June 01	September 23	Exceedence	Action Required
			2013	2013	2013	2013		
Nitrate	10	mg/L	1.54	1.27	1.06	1.43	No	No
Nitrite	1	mg/L	< 0.02	<0.02	<0.02	<0.02	No	No
THM	0.15	mg/L	30.6 ug/L	21.4ug/L	31.8 ug/L	30.2 ug/L	No	No

\*\*\*THM Running average value is. 28.5 mg/L.

**ANNUAL REPORT  
2013**

**Drinking Water Surveillance Program**

Appendix B4-A

Summary of chemical, Physical and Operational Parameters										
Raw Water										
Parameter	M.A.C. or I.M.A.C.	Units	Well #1 March 14, 2013	Well #4 March 14, 2013	Well #5 March 14, 2013	Well #2 Oct 29, 2013	Well #3 Oct 29, 2013	Well #5 Oct 29, 2013	Exceedence	Action Required
Alkalinity	30 - 500	mg/L	322	267	327	315	286	326	No	No
Ammonia & Ammonium	0.15	mg/L	---	---	---	0.008	0.008	0.008	No	No
Chloride	250	mg/L	59.4	65.4	71.8	55	61.8	57	No	No
Colour	5	TCU	3.5	1.6	2.2	2.3	1.2	4.4	No	No
Conductivity	?	uS/cm	808	777	892	786	803	822	?	?
Dissolved Organic Carbon	5	mg/L	2.5	1.3	1.9	2	1.3	2.5	No	No
Dissolved Inorganic Carbon	?	mg/L	80.6	65.3	80	79.5	71.1	79.4	?	?
Dissolved Solids	?	mg/L	---	---	---	---	---	---	?	?
Fluoride	1.5 - 2.4	mg/L	0.06	0.05	0.07	0.09	0.07	0.08	No	No
Hardness	80 - 100	mg/L	---	---	---	---	---	---	Yes <sup>(1)</sup>	No
Langliers Index	?	---	---	---	---	---	---	---	?	?
Nitrate	10	mg/L	---	---	---	1.489	1.939	0.176	No	No
Nitrite	1	mg/L	---	---	---	0.001	0.001	0.004	No	No
pH	6.5 - 8.5	---	7.66	7.82	7.69	7.71	7.82	7.71	No	No
pH Saturated	6.5 - 8.6	---	---	---	---	---	---	---	No	No
Phosphorus	?	mg/L	---	---	---	0.002	0.0023	0.0016	?	?
Silicon	?	mg/L	4.52	4.24	4.58	4.34	4.34	4.52	?	?
Sulphate	150 - 500	mg/L	15.3	32.6	38.8	17.2	42	37.5	No	No
Turbidity	1	FTU	---	---	---	---	---	---	No	No
Phosphate	?	mg/L	---	---	---	0.002	0.0023	0.0016	?	?
Total Kjeldahl Nitrogen (TKN)	?	mg/L	---	---	---	---	---	---	?	?

<sup>(1)</sup> The M.A.C of 80 - 100 mg/L for Hardness is an Aesthetic Objective. If hardness Exceeds 500 mg/L further action may be ordered.

**ANNUAL REPORT  
2013  
Drinking Water Surveillance Program**

Appendix B4-B

Summary of Chemical, Physical and Operational Parameters						
Treated						
Parameter	M.A.C. or I.M.A.C.	Units	Reservoir March 14 2013	Reservoir Oct 29, 2013	Exceedence	Action Required
Alkalinity	30 - 500	mg/L	302	315	No	No
Ammonia & Ammonium (N)	0.15	mg/L	—	0.01	No	No
Chloride	250	mg/L	66	57.8	No	No
Colour	5	TCU	2.8	2.6	No	No
Conductivity	?	uS/cm	830	778	?	?
Dissolved Organic Carbon	5	mg/L	1.8	2	No	No
Dissolved Inorganic Carbon	?	mg/L	71.4	77.3	?	?
Dissolved Solids	?	mg/L	—	—	?	?
Fluoride	1.5 - 2.4	mg/L	0.07	0.09	No	No
Hardness	80 - 100	mg/L	—	—	No	No
Langliers Index	?	—	—	—	?	?
Nitrate	10	mg/L	—	1.469	No	No
Nitrite	1	mg/L	—	0.001	No	No
pH	6.5 - 8.5	—	8.02	8.02	No	No
pH Saturated	6.5 - 8.6	—	—	—	No	No
Phosphorus	?	mg/L	—	0.0018	?	?
Silicon	?	mg/L	4.44	4.34	?	?
Sulphate	150 - 500	mg/L	31.6	18.3	No	No
Phosphate	?	mg/L	—	0.0018	?	?
Total Kjeldahl Nitrogen (TKN)	?	mg/L	—	—	?	?

<sup>1</sup>The M.A.C. of 80 - 100 mg/L for Hardness is an aesthetic objective. When Hardness exceeds 500 mg/L, corrective measures may be ordered.

**ANNUAL REPORT  
2013**

**Drinking Water Surveillance Program**

Appendix B5-A

Parameter	M.A.C. or I.M.A.C.	Units	INORGANICS Raw Water					Well #5 Oct 29, 2013	Well #3 Oct 29, 2013	Well #5 Oct 29, 2013	Exceedence	Action Required
			Well #1 March 14, 2013	Well #4 March 14, 2013	Well 5 March 14, 2013	Well #2 Oct 29, 2013	Well #3 Oct 29, 2013					
Aluminum	0.1	mg/L	0.7 ug/L	0.5 ug/L	0.6 ug/L	0.8 ug/L	0.5 ug/L	0.5 ug/L	0.9 ug/L	No	No	
Antimony	0.0001	mg/L	0.7 ug/L	0.6 ug/L	0.7 ug/L	0.7 ug/L	0.8 ug/L	0.8 ug/L	0.9 ug/L	No	No	
Arsenic	0.025	mg/L	0.3 ug/L	0.3 ug/L	0.3 ug/L	0.2 ug/L	0.2 ug/L	0.2 ug/L	0.3 ug/L	No	No	
Barium	?	mg/L	48 ug/L	26.8 ug/L	27.4 ug/L	44.4 ug/L	39 ug/L	39 ug/L	48.6 ug/L	No	No	
Beryllium	?	mg/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	No	No	
Boron	5	mg/L	20.2 ug/L	13.4 ug/L	15.3 ug/L	18.1 ug/L	16.3 ug/L	16.3 ug/L	12.5 ug/L	No	No	
Cadmium	0.005	mg/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0.1 ug/L	No	No	
Calcium	?	mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	No	No	
Chromium	0.05	mg/L	0.5 ug/L	0.8 ug/L	0.4 ug/L	0.2 ug/L	0.3 ug/L	0.3 ug/L	0.1 ug/L	No	No	
Cobalt	?	mg/L	0.2 ug/L	0.1 ug/L	0.3 ug/L	0.2 ug/L	0.2 ug/L	0.2 ug/L	0.5 ug/L	No	No	
Copper	1	mg/L	1.9 ug/L	1.9 ug/L	3.5 ug/L	2.2 ug/L	2.5 ug/L	2.5 ug/L	4.9 ug/L	No	No	
Iron	0.3	mg/L	60 ug/L	0 ug/L	0 ug/L	20 ug/L	0 ug/L	0 ug/L	80 ug/L	No	No	
Lead	0.01	mg/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0.1 ug/L	0.1 ug/L	0.2 ug/L	No	No	
Magnesium	?	mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	No	No	
Manganese	0.05	mg/L	59.4 <sup>(1)</sup> ug/L	0.3 ug/L	19.7 ug/L	28 ug/L	6.6 ug/L	6.6 ug/L	37.4 ug/L	Yes <sup>(1)</sup>	No	
Molybdenum	?	mg/L	0.2 ug/L	0.2 ug/L	0.3 ug/L	0.3 ug/L	0.3 ug/L	0.3 ug/L	0.3 ug/L	No	No	
Nickel	?	mg/L	0.7 ug/L	0.5 ug/L	1.6 ug/L	0.7 ug/L	0.5 ug/L	0.5 ug/L	2.3 ug/L	No	No	
Potassium	?	mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	No	No	
Selenium	0.01	mg/L	0.4 ug/L	0.8 ug/L	1.1 ug/L	0.2 ug/L	1.1 ug/L	1.1 ug/L	0.7 ug/L	No	No	
Silver	?	mg/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	No	No	
Sodium	20	mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	-- mg/L	No	No	
Strontium	?	mg/L	137 ug/L	102 ug/L	146 ug/L	126 ug/L	115 ug/L	115 ug/L	139 ug/L	Yes <sup>(2)</sup>	No	
Thallium	?	mg/L	0 ug/L	0 ug/L	0.1 ug/L	0 ug/L	0 ug/L	0 ug/L	0.1 ug/L	No	No	
Titanium	?	mg/L	0.3 ug/L	0.6 ug/L	0.6 ug/L	0.4 ug/L	0.8 ug/L	0.8 ug/L	0.8 ug/L	No	No	
Uranium	0.1	mg/L	0.9 ug/L	0.6 ug/L	3.1 ug/L	0.9 ug/L	1.4 ug/L	1.4 ug/L	3.5 ug/L	No	No	
Vanadium	?	mg/L	0.2 ug/L	0.2 ug/L	0.5 ug/L	0.2 ug/L	0.4 ug/L	0.4 ug/L	0.5 ug/L	No	No	
Zinc	5	mg/L	1.4 ug/L	4.2 ug/L	1.4 ug/L	0.8 ug/L	6.5 ug/L	6.5 ug/L	4.7 ug/L	No	No	

<sup>1</sup>The M.A.C. of 0.05 mg/L (50 ug/L) for manganese is a colour related aesthetic objective. Like Iron, Manganese may stain laundered items and plumbing fixtures and in excessive concentrations, may cause undesirable tastes in beverages and drinking water.

<sup>2</sup>The Ontario Spills Action Center and the Thunder Bay District Health Unit, Medical Officer of Health have been notified. Warning notices have been posted and local doctors advised to alert persons on a sodium restricted diet to use another potable water supply for cooking and drinking purposes. When sodium levels exceed 200 ug/L, corrective measures may be ordered.

**ANNUAL REPORT  
2013  
Drinking Water Surveillance Program**

Appendix B5-B

INORGANICS									
Treated Water									
Parameter	M.A.C. or I.M.A.C.	Units	Reservoir March 14, 2013	Reservoir Oct 29, 2013	Distribution March 14, 2013	Distribution Oct 29, 2013	Exceedence	Action Required	
Aluminum	0.1	mg/L	1.6 ug/L	1 ug/L	1.3 ug/L	1 ug/L	No	No	
Antimony	0.006	mg/L	0.6 ug/L	0.6 ug/L	0.6 ug/L	0.7 ug/L	No	No	
Arsenic	0.025	mg/L	0.3 ug/L	0.2 ug/L	0.3 ug/L	0.2 ug/L	No	No	
Barium	?	mg/L	41.6 ug/L	43.5 ug/L	40.1 ug/L	43.4 ug/L	?	?	
Beryllium	?	mg/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	?	?	
Boron	5	mg/L	17.4 ug/L	18 ug/L	16.7 ug/L	17.2 ug/L	No	No	
Cadmium	0.005	mg/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	No	No	
Calcium	?	mg/L	— mg/L	— mg/L	— mg/L	— mg/L	?	?	
Chromium	0.05	mg/L	0.6 ug/L	2.2 ug/L	0.5 ug/L	0.5 ug/L	No	No	
Cobalt	?	mg/L	0.2 ug/L	0.2 ug/L	0.2 ug/L	0.2 ug/L	?	?	
Copper	1	mg/L	91.3 ug/L	113 ug/L	189 ug/L	237 ug/L	No	No	
Iron	0.3	mg/L	10 ug/L	20 ug/L	10 ug/L	20 ug/L	No	No	
Lead	0.01	mg/L	0.2 ug/L	0.1 ug/L	0.1 ug/L	0.2 ug/L	No	No	
Magnesium	?	mg/L	— mg/L	— mg/L	— mg/L	— mg/L	?	?	
Manganese	0.05	mg/L	23 ug/L	22.3 ug/L	12.8 ug/L	11.2 ug/L	No	No	
Molybdenum	?	mg/L	0.2 ug/L	0.2 ug/L	0.2 ug/L	0.2 ug/L	?	?	
Nickel	?	mg/L	0.8 ug/L	0.8 ug/L	0.7 ug/L	0.9 ug/L	?	?	
Potassium	?	mg/L	— mg/L	— mg/L	— mg/L	— mg/L	?	?	
Selenium	0.01	mg/L	1.1 ug/L	0.2 ug/L	1.3 ug/L	0.2 ug/L	No	No	
Silver	?	mg/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	?	?	
Sodium	20	mg/L	— mg/L	— mg/L	— mg/L	— mg/L	?	?	
Strontium	?	mg/L	124 ug/L	126 ug/L	121 ug/L	127 ug/L	Yes <sup>(2)</sup>	Yes	
Thallium	?	mg/L	0 ug/L	0 ug/L	0 ug/L	0 ug/L	?	?	
Titanium	?	mg/L	0.6 ug/L	0.4 ug/L	0.6 ug/L	0.5 ug/L	?	?	
Uranium	0.1	mg/L	1.5 ug/L	0.9 ug/L	1.5 ug/L	1 ug/L	No	No	
Vanadium	?	mg/L	0.4 ug/L	0.3 ug/L	0.3 ug/L	0.3 ug/L	?	?	
Zinc	5	mg/L	3.1 ug/L	3.3 ug/L	2.4 ug/L	3.8 ug/L	No	No	

<sup>1</sup>The Ontario Spills Action Center and the Thunder Bay District Health Unit, Medical Officer of Health have been notified. Warning notices have been posted and local doctors advised to alert persons on a sodium restricted diet to use another potable water supply for cooking and drinking purposes. When sodium levels exceed 200 ug/L, corrective measures may be ordered.

T.N.P. - Test Not Performed

**ANNUAL REPORT  
2013  
Summary of Weekly Bacteriological Sampling**

**Appendix C-1**

Raw Water						
# of Detectable Results						
Adverse Quality Indicator <sup>(1)</sup>						
Month	Number of Samples	Total <sup>1</sup> Coliform	Fecal <sup>1</sup> Coliform	E-Coli <sup>1</sup>	Exceedence	Action Required
January	25	A	A	A	No	No
February	20	A	A	A	No	No
March	20	A	A	A	No	No
April	25	A	A	A	No	No
May	20	A	A	A	No	No
June	20	A	A	A	No	No
July	25	A	A	A	No	No
August	20	A	A	A	No	No
September	20	A	A	A	No	No
October <sup>*2</sup>	20	P	A	A	Yes	No
November	20	A	A	A	No	No
December	25	A	A	A	No	No
Annual	260				No	No

<sup>1</sup> There are no maximum or interim maximum acceptable concentrations for Coliforms, Fecal Coliforms, or E-Coli. Rather, the presence of any of these parameters in a drinking water sample indicates deteriorating or adverse water quality. The detection of an adverse indicator in an unchlorinated raw water sample that will be subject to the treatment process poses no significant risk to human health.

A                      Absent  
P                      Presence

\*2: Sample collected on 15/10/13 yielded a presence of Total Coliform. Additional Sample collected on 24/10/13 yielded an absent result.

# ANNUAL REPORT 2013

## Summary of Weekly Bacteriological Sampling

Appendix C-2

Treated Water Reservoir									
# of Detectable Results									
Adverse Quality Indicator <sup>1</sup>									
Month	Number of Samples	Total <sup>1</sup> Coliforms	Fecal <sup>1</sup> Coliforms	E-Coli <sup>1</sup>	H.P.C. Number of Tests	Range of Results		Exceedence	Action Required
						C.F.U. / 100 ml	Minimum Maximum		
January	5	A	A	A	5	0	1	N	N
February	4	A	A	A	4	0	1	N	N
March	4	A	A	A	4	0	0	N	N
April	5	A	A	A	5	0	0	N	N
May	4	A	A	A	4	0	0	N	N
June	4	A	A	A	4	0	1	N	N
July	5	A	A	A	5	0	0	N	N
August	4	A	A	A	4	0	0	N	N
September	4	A	A	A	4	0	4	N	N
October	4	A	A	A	4	0	1	N	N
November	4	A	A	A	4	0	0	N	N
December	5	A	A	A	5	0	0	N	N
Annual	52	A	A	A	52	0	4	N	N

<sup>1</sup> There are no maximum or interim maximum acceptable concentrations for Coliforms, Fecal Coliforms, or E-Coli. Rather, the presence of any of these parameters in a drinking water sample indicates deteriorating or adverse water quality.

A Absent  
P Present

# ANNUAL REPORT 2013

## Summary of Weekly Bacteriological Sampling

Appendix C-3											
Distribution System											
Number of Detectable Results											
Adverse Quality Indicators <sup>(1)</sup>											
Month	Number of Samples	Total <sup>1</sup> Coliforms	Fecal <sup>1</sup> Coliforms	E-Coli <sup>1</sup>	H.P.C. Number of Tests	Range of Results		Exceedence	Action Required		
						C.F.U. / 100 ml	Minimum Maximum				
January	20	A	A	A	20	0	2	N	N		
February	16	A	A	A	16	0	6	N	N		
March	16	A	A	A	16	0	2	N	N		
April	20	A	A	A	20	0	11	N	N		
May	16	A	A	A	16	0	8	N	N		
June	16	A	A	A	16	0	184	N	N		
July	20	A	A	A	20	0	19	N	N		
August	16	A	A	A	16	0	5	N	N		
September	16	A	A	A	16	0	1	N	N		
October	16	A	A	A	16	0	12	N	N		
November	16	A	A	A	16	0	31	N	N		
December	20	A	A	a	20	0	1	N	N		
Annual	208				208	0	184	N	N		

<sup>1</sup> There are no maximum or interim maximum acceptable concentrations for Coliforms, Fecal Coliforms, or E-Coli. Rather, the presence of any of these parameters in a drinking water sample indicates deteriorating or adverse water quality.

A Absent  
P Present



# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-a

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results			Exceedence	Action Required
				N.T.U				
				Average	Minimum	Maximum		
Turbidity	1 N.T.U	January	62	0.206	0.15	0.29	N	N
		February	56	0.199	0.14	0.28	N	N
		March	62	0.225	0.01	0.33	N	N
		April	60	0.241	0.13	0.36	N	N
		May	62	0.201	0.13	0.33	N	N
		June	60	0.178	0.09	0.29	N	N
		July	62	0.152	0.09	0.24	N	N
		August	62	0.159	0.08	0.28	N	N
		September	60	0.180	0.11	0.30	N	N
		October	62	0.297	0.19	0.41	N	N
		November	60	0.296	0.21	0.42	N	N
		December	62	0.217	0.14	0.37	N	N
Annual	730	0.212	0.01	0.42	N	N		

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results			Exceedence	Action Required
				T.C.U.				
				Average	Minimum	Maximum		
Colour	5 T.C.U.	January	62	0.0	0.0	0.0	No	No
		February	56	0.0	0.0	0.0	No	No
		March	62	0.0	0.0	0.0	No	No
		April	60	0.0	0.0	0.0	No	No
		May	62	0.0	0.0	0.0	No	No
		June	60	0.0	0.0	0.0	No	No
		July	62	0.0	0.0	0.0	No	No
		August	62	0.0	0.0	0.0	No	No
		September	60	0.0	0.0	0.0	No	No
		October	62	0.0	0.0	0.0	No	No
		November	60	0.0	0.0	0.0	No	No
		December	62	0.0	0.0	0.0	No	No
		Annual	730	0.0	0.0	0.0	No	No

Appendix D1-b

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-c

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Average °C	Exceedence	Action Required
Temperature	4°C to 15°C	January	62	6.8	No	No
		February	56	6.8	No	No
		March	62	7.0	No	No
		April	60	7.0	No	No
		May	62	7.2	No	No
		June	60	7.6	No	No
		July	62	7.9	No	No
		August	62	7.9	No	No
		September	60	7.8	No	No
		October	62	7.6	No	No
		November	60	7.2	No	No
		December	62	6.8	No	No
		Annual	730	7.3	No	No

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-d

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Average	Exceedence	Action Required
pH	6.5 to 8.5	January	62	7.7	No	No
		February	56	7.6	No	No
		March	62	7.7	No	No
		April	60	7.6	No	No
		May	62	7.6	No	No
		June	60	7.7	No	No
		July	62	7.7	No	No
		August	62	7.8	No	No
		September	60	7.8	No	No
		October	62	7.7	No	No
		November	60	7.8	No	No
		December	62	7.7	No	No
Annual	730	7.7	No	No		

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-e

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results mg/L			Exceedence	Action Required
				Average	Minimum	Maximum		
Free Chlorine Residual	0.05 mg/L (minium) to 4.00 mg/L (maximum)	January	62	0.98	0.85	1.18	No	No
		February	56	1.03	0.93	1.14	No	No
		March	62	0.91	0.67	1.04	No	No
		April	60	0.89	0.65	1.01	No	No
		May	62	0.90	0.75	1.00	No	No
		June	60	0.78	0.53	0.94	No	No
		July	62	0.96	0.69	1.15	No	No
		August	62	0.88	0.70	1.02	No	No
		September	60	1.00	0.73	1.22	No	No
		October	62	1.02	0.89	1.12	No	No
		November	60	1.12	0.98	1.25	No	No
		December	62	1.02	0.71	1.35	No	No
Annual	730	0.96	0.53	1.35	No	No		

(1) Ontario Spills Action Centre, Thunder Bay District Health Unit and Ministry of the Environment were informed. Sodium Hypochlorite dosage rate increased until Free Chlorine Residual leaving the pumphouse was above 0.20 mg/L. Distribution Samples taken to confirm that Free Chlorine Residual was 0.20 mg/L or greater.


**2013**  
**Annual Report**  
**Monthly Turbidity Readings**

Appendix D1-g

Date	Raw Well 1 NTU	Raw Well 2 NTU	Raw Well 3 NTU	Raw Well 4 NTU	Raw Well 5 NTU
28-Jan-13	0.11	0.14	0.21	0.21	0.13
19-Feb-13	0.14	0.19	0.06	0.11	0.07
12-Mar-13	0.22	0.24	0.18	0.11	0.15
25-Apr-13	0.15	0.22	0.25	0.11	0.1
17-May-13	0.2	0.11	0.1	0.14	0.12
10-Jun-13	0.05	0.09	0.27	0.18	0.07
9-Jul-13	0.1	0.11	0.21	0.17	0.09
12-Aug-13	0.14	0.16	0.2	0.12	0.14
16-Sep-13	0.11	0.18	0.24	0.14	0.12
9-Oct-13	0.27	0.11	0.12	0.21	0.18
14-Nov-13	0.11	0.17	0.19	0.22	0.11
11-Dec-13	0.17	0.2	0.11	0.09	0.15
<b>Min</b>	<b>0.05</b>	<b>0.09</b>	<b>0.06</b>	<b>0.09</b>	<b>0.07</b>
<b>Max</b>	<b>0.27</b>	<b>0.24</b>	<b>0.27</b>	<b>0.22</b>	<b>0.18</b>
<b>Average</b>	<b>0.15</b>	<b>0.16</b>	<b>0.18</b>	<b>0.15</b>	<b>0.12</b>



# Raw Well Turbidities



— Raw Well 1      — Raw Well 2      — Raw Well 3      — Raw Well 4      — Raw Well 5

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-g Zone 1 FC

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results			Exceedence	Action Required
				mg/L				
				Average	Minimum	Maximum		
Free Chlorine Residual	0.05 mg/L (minimum) to 4.00 mg/L (maximum)	January	31	0.90	0.70	1.06	No	No
		February	28	0.92	0.81	1.07	No	No
		March	31	0.85	0.68	0.98	No	No
		April	30	0.82	0.49	0.94	No	No
		May	31	0.83	0.71	0.93	No	No
		June	30	0.71	0.45	0.85	No	No
		July	31	0.86	0.52	1.06	No	No
		August	31	0.79	0.52	1.06	No	No
		September	30	0.82	0.47	1.20	No	No
		October	31	0.90	0.74	1.03	No	No
		November	30	1.03	0.89	1.18	No	No
		December	31	0.95	0.69	1.24	No	No
Annual	365	0.86	0.45	1.24	No	No		

(1) Ontario Spills Action Centre, Thunder Bay District Health Unit and Ministry of the Environment were informed. Sodium Hypochlorite dosage rate increased until Free Chlorine Residual leaving the pumphouse was above 0.20 mg/L. Distribution Samples taken to confirm that Free Chlorine Residual was 0.20 mg/L or greater.

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

### Appendix D1-g Zone 1 pH

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Average	Exceedence	Action Required
Distribution Zone #1 pH	6.5 to 8.5	January	31	7.8	No	No
		February	28	7.7	No	No
		March	31	7.8	No	No
		April	30	7.7	No	No
		May	31	7.7	No	No
		June	30	7.7	No	No
		July	31	7.7	No	No
		August	31	7.8	No	No
		September	30	7.8	No	No
		October	31	7.8	No	No
		November	30	7.8	No	No
		December	31	7.8	No	No
		Annual	365	7.8	No	No

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-g Zone 1 TC

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results mg/L			Exceedence	Action Required
				Average	Minimum	Maximum		
				Total Chlorine Residual	0.05 mg/L (minium) to 4.00 mg/L (maximum)	January		
		February	28	1.08	0.96	1.23	No	No
		March	31	1.00	0.82	1.11	No	No
		April	30	0.99	0.98	1.15	No	No
		May	31	0.99	0.83	1.11	No	No
		June	30	0.84	0.51	1.02	No	No
		July	31	0.98	0.64	1.25	No	No
		August	31	0.92	0.62	1.18	No	No
		September	30	0.97	0.55	1.50	No	No
		October	31	1.10	0.90	1.27	No	No
		November	30	1.20	1.02	1.36	No	No
		December	31	1.11	0.86	1.46	No	No
		Annual	365	1.02	0.51	1.50	No	No

(1) Ontario Spills Action Centre, Thunder Bay District Health Unit and Ministry of the Environment were informed. Sodium Hypochlorite dosage rate increased until Free Chlorine Residual leaving the pumphouse was above 0.20 mg/L. Distribution Samples taken to confirm that Free Chlorine Residual was 0.20 mg/L or greater.

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-g Zone 2 FC

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results mg/L			Exceedence	Action Required
				Average	Minimum	Maximum		
Distribution Zone 2 Free Chlorine Residual	0.05 mg/L (minium) to 4.00 mg/L (maximum)	January	31	0.86	0.73	0.98	No	No
		February	28	0.88	0.78	0.96	No	No
		March	31	0.81	0.61	0.94	No	No
		April	30	0.79	0.55	0.87	No	No
		May	31	0.80	0.66	0.97	No	No
		June	30	0.67	0.36	0.82	No	No
		July	31	0.76	0.55	1.04	No	No
		August	31	0.69	0.52	0.93	No	No
		September	30	0.78	0.53	1.03	No	No
		October	31	0.69	0.49	0.96	No	No
		November	30	0.83	0.69	1.06	No	No
		December	31	0.80	0.56	1.16	No	No
Annual	365	0.78	0.36	1.16	No	No		

(1) Ontario Spills Action Centre, Thunder Bay District Health Unit and Ministry of the Environment were informed. Sodium Hypochlorite dosage rate increased until Free Chlorine Residual leaving the pumphouse was above 0.20 mg/L. Distribution Samples taken to confirm that Free Chlorine Residual was 0.20 mg/L or greater.

# ANNUAL REPORT

2013

## Summary of Laboratory Testing and Operational Parameters

		Appendix D1-g Zone 2 pH				
Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Average	Exceedence	Action Required
Distribution Zone #2 pH	6.5 to 8.5	January	31	7.8	No	No
		February	28	7.8	No	No
		March	31	7.8	No	No
		April	30	7.7	No	No
		May	31	7.7	No	No
		June	30	7.7	No	No
		July	31	7.7	No	No
		August	31	7.8	No	No
		September	30	7.8	No	No
		October	31	7.8	No	No
		November	30	7.8	No	No
		December	31	7.8	No	No
		Annual	365	7.8	No	No

# ANNUAL REPORT

2013

## Summary of Laboratory Testing and Operational Parameters

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results			Exceedence	Action Required
				mg/L				
				Average	Minimum	Maximum		
Distribution Zone 2 Total Chlorine Residual	0.05 mg/L (minium) to 4.00 mg/L (maximum)	January	31	1.03	0.88	0.82	No	No
		February	28	1.04	0.95	1.17	No	No
		March	31	0.96	0.79	1.13	No	No
		April	30	0.96	0.71	1.10	No	No
		May	31	0.95	0.77	1.04	No	No
		June	30	0.81	0.56	0.96	No	No
		July	31	0.87	0.67	1.12	No	No
		August	31	0.80	0.65	1.09	No	No
		September	30	0.91	0.60	1.22	No	No
		October	31	0.83	0.60	1.13	No	No
		November	30	0.97	0.80	1.24	No	No
		December	31	0.96	0.81	1.33	No	No
Annual	365	0.92	0.56	1.33	No	No		

Appendix D1-g Zone 2 TC



# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-g Zone 3 FC

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results mg/L			Exceedence	Action Required
				Average	Minimum	Maximum		
				Distribution Zone 3 Free Chlorine Residual	0.05 mg/L (minium) to 4.00 mg/L (maximum)	January		
		February	28	0.84	0.74	0.98	No	No
		March	31	0.78	0.61	0.86	No	No
		April	30	0.74	0.52	0.87	No	No
		May	31	0.73	0.65	0.88	No	No
		June	30	0.58	0.34	0.69	No	No
		July	31	0.60	0.39	0.88	No	No
		August	31	0.54	0.26	0.79	No	No
		September	30	0.57	0.22	0.74	No	No
		October	31	0.61	0.44	0.72	No	No
		November	30	0.86	0.71	0.96	No	No
		December	31	0.82	0.62	1.07	No	No
		Annual	365	0.70	0.22	1.07	No	No

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

### Appendix D1-g Zone 3 pH

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Average	Exceedence	Action Required
Distribution Zone #3 pH	6.5 to 8.5	January	31	7.8	No	No
		February	28	7.7	No	No
		March	31	7.8	No	No
		April	30	7.7	No	No
		May	31	7.7	No	No
		June	30	7.7	No	No
		July	31	7.8	No	No
		August	31	7.8	No	No
		September	30	7.8	No	No
		October	31	7.8	No	No
		November	30	7.8	No	No
		December	31	7.8	No	No
		Annual	365	7.8	No	No

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-g Zone 3 TC

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results mg/L			Exceedence	Action Required
				Average	Minimum	Maximum		
Distribution Zone 3 Total Chlorine Residual	0.05 mg/L (minimum) to 4.00 mg/L (maximum)	January	31	0.93	0.80	1.12	No	No
		February	28	0.99	0.89	1.08	No	No
		March	31	0.92	0.78	1.02	No	No
		April	30	0.89	0.63	0.99	No	No
		May	31	0.88	0.79	0.98	No	No
		June	30	0.70	0.47	0.86	No	No
		July	31	0.70	0.47	1.04	No	No
		August	31	0.65	0.34	0.90	No	No
		September	30	0.68	0.30	0.87	No	No
		October	31	0.74	0.62	0.91	No	No
		November	30	1.01	0.82	1.18	No	No
		December	31	0.97	0.74	1.22	No	No
Annual	365	0.63	0.30	1.22	No	No		

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

Appendix D1-g Zone 4 FC

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results mg/L			Exceedence	Action Required
				Average	Minimum	Maximum		
				Distribution Zone 4 Free Chlorine Residual	0.05 mg/L (minimum) to 4.00 mg/L (maximum)	January		
		February	28	0.89	0.76	1.00	No	No
		March	31	0.82	0.63	0.97	No	No
		April	30	0.80	0.50	0.88	No	No
		May	31	0.79	0.70	0.94	No	No
		June	30	0.79	0.56	1.02	No	No
		July	31	0.77	0.54	0.99	No	No
		August	31	0.70	0.53	1.09	No	No
		September	30	0.83	0.57	1.08	No	No
		October	31	0.82	0.63	0.91	No	No
		November	30	0.93	0.83	1.13	No	No
		December	31	0.84	0.62	1.07	No	No
		Annual	365	0.82	0.50	1.13	No	No

(1) Ontario Spills Action Centre, Thunder Bay District Health Unit and Ministry of the Environment were informed. Sodium Hypochlorite dosage rate increased until Free Chlorine Residual leaving the pumphouse was above 0.20 mg/L. Distribution Samples taken to confirm that Free Chlorine Residual was 0.20 mg/L or greater.

# ANNUAL REPORT 2013

## Summary of Laboratory Testing and Operational Parameters

### Appendix D1-g Zone 4 pH

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Average	Exceedence	Action Required
Distribution Zone #4 pH	6.5 to 8.5	January	31	7.8	No	No
		February	28	7.7	No	No
		March	31	7.8	No	No
		April	30	7.7	No	No
		May	31	7.7	No	No
		June	30	7.7	No	No
		July	31	7.8	No	No
		August	31	7.8	No	No
		September	30	7.8	No	No
		October	31	7.8	No	No
		November	30	7.8	No	No
		December	31	7.8	No	No
		Annual	365	7.8	No	No

**ANNUAL REPORT  
2013**

**Summary of Laboratory Testing and Operational Parameters**

**Appendix D1-g Zone 4 TC**

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results			Exceedence	Action Required
				Average	mg/L			
					Minimum	Maximum		
Distribution Zone 4 Total Chlorine Residual	0.05 mg/L (minium) to 4.00 mg/L (maximum)	January	31	1.02	0.85	1.40	No	No
		February	28	1.04	0.90	1.15	No	No
		March	31	0.98	0.79	1.13	No	No
		April	30	0.95	0.69	1.07	No	No
		May	31	0.94	0.81	1.10	No	No
		June	30	0.79	0.56	1.02	No	No
		July	31	0.89	0.63	1.17	No	No
		August	31	0.83	0.61	1.24	No	No
		September	30	0.97	0.68	1.27	No	No
		October	31	0.98	0.85	1.12	No	No
		November	30	1.09	0.98	1.30	No	No
		December	31	0.99	0.74	1.23	No	No
Annual	365	0.63	0.56	1.40	No	No		

# ANNUAL REPORT 2013

## Summary of Daily On-Line Instrumentation

Appendix D2-a

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results N.T.U			Exceedence	Action Required
				Average	Minimum	Maximum		
				Turbidity	1 N.T.U	January		
Hach 1720D Turbidimeter		February	56	0.127	0.085	1.190	No	No
		March	62	0.122	0.092	0.226	No	No
		April	60	0.099	0.079	0.120	No	No
		May	62	0.133	0.088	0.390	No	No
		June	60	0.118	0.077	0.191	No	No
		July	62	0.098	0.075	0.134	No	No
		August	62	0.093	0.075	0.120	No	No
		September	60	0.109	0.082	0.239	No	No
		October	62	0.193	0.128	0.649	No	No
		November	60	0.189	0.136	0.234	No	No
		December	62	0.150	0.086	1.000	No	No
		Annual	730	0.128	0.009	1.190	No	No



# ANNUAL REPORT 2013

## Summary of Daily On-Line Instrumentation

Appendix D2-b

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Range of Results			Exceedence	Action Required
				(mg/L)	(mg/L)	(mg/L)		
				Average	Minimum	Maximum		
Chlorine Residual Hach CL17 Free Chlorine Analyzer	0.05 mg/L (minimum) to 4.00 mg/L (maximum)	January	62	1.03	0.89	1.20	No	No
		February	56	1.08	1.01	1.19	No	No
		March	62	0.95	0.70	1.07	No	No
		April	60	0.94	0.68	1.05	No	No
		May	62	0.97	0.89	1.10	No	No
		June	60	0.81	0.53	0.96	No	No
		July	62	1.03	0.72	1.22	No	No
		August	62	0.93	0.73	1.13	No	No
		September	60	1.06	0.77	1.34	No	No
		October	62	1.07	0.90	1.22	No	No
		November	60	1.20	1.06	1.34	No	No
		December	62	1.06	0.69	1.48	No	No
Annual	730	1.01	0.53	1.48	No	No		

(1) The Ontario Spills Action Centre, Thunder Bay District Health Unit and the Ministry of Environment must be notified. Chlorine dosage rate is increased to return Free Chlorine Residual to 0.20 mg/L leaving the Treatment Plant. Distribution Samples are taken to confirm Free Chlorine is greater than 0.20 mg/L or higher.

# ANNUAL REPORT

2013

## Summary of Daily On-Line Instrumentation

Appendix D2-c

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Average	Exceedence	Action Required
pH	6.5 to 8.5	January	62	7.71	No	No
		February	56	7.68	No	No
Hach EC 310		March	62	7.72	No	No
		April	60	7.67	No	No
		May	62	7.67	No	No
		June	60	7.70	No	No
		July	62	7.71	No	No
		August	62	7.60	No	No
		September	60	7.62	No	No
		October	62	7.57	No	No
		November	60	7.65	No	No
		December	62	7.64	No	No
Annual	730	7.66	No	No		

# ANNUAL REPORT 2013

## Summary of Daily On-Line Instrumentation

Appendix D2-d

Parameter	M.A.C. or I.M.A.C.	Month	Number of Samples	Average		Exceedence	Action Required
				°C			
Temperature  Hach EC 310	4 °C to 15 °C	January	62	7.1		No	No
		February	56	7.2		No	No
		March	62	7.3		No	No
		April	60	7.3		No	No
		May	62	7.3		No	No
		June	60	7.7		No	No
		July	62	8.0		No	No
		August	62	8.1		No	No
		September	60	8.0		No	No
		October	62	7.8		No	No
		November	60	7.4		No	No
		December	62	7.0		No	No
Annual	730	7.5		No	No		

**Annual UV Treatment**  
**2013**  
**Dosage**

Appendix D2E

Date	Well#1 & 2			Well # 3 & 4			Well #5		
	min	max	average	min	max	average	min	max	average
January	0	264	145	0	80	64	0	198	41
February	0	173	107	0	117	70	0	264	86
March	0	121	79	0	160	83	0	242	84
April	0	99	80	0	193	133	0	169	57
May	0	278	99	0	435	118	0	119	57
June	0	351	116	0	593	74	0	302	64
July	0	302	76	0	605	112	0	242	64
August	0	339	92	0	46	10	0	326	71
September	0	488	70	0	66	12	0	411	129
October	0	155	69	0	55	6	0	460	124
November	0	121	64	0	460	163	0	213	121
December	0	88	69	0	343	221	0	314	88
Annual (min, max, Average)	0	488	89	0	605	89	0	460	82

UV Dose are measured using mJ/cm<sup>2</sup> units. Zero readings are measured during well shut down and the average is based on up to 10 000 readings. These reactors are designed to achieve maximum inactivation at a minimum dosage rate of 42 mJ/cm<sup>2</sup>

**ANNUAL REPORT**  
**2013**  
**SUMMARY OF MONTHLY FLOWS & COMPLIANCE SHEET - WATER**

YEAR 2013	WELL 1 FLOW m3	WELL 2 FLOW m3	WELL 3 FLOW m3	WELL 4 FLOW m3	WELL 5 FLOW m3	WELL FIELD		TREATED FLOW m3	PERCENTAGE RAW WATER		PERCENTAGE TREATED WATER	
						FLOW m3	FLOW m3		WELL FIELD	WELL FIELD	WELL FIELD	WELL FIELD
JANUARY	2626.80	13443.15	5826.97	6280.06	2611.32	30788.30	30344.51	28919.42	-1.46	-6.07	-4.93	
FEBRUARY	5460.39	1313.19	5243.86	2682.83	1413.41	28813.68	28783.73	27453.43	-0.10	-4.72	-4.85	
MARCH	7301.90	1426.70	13649.52	707.92	10496.40	33582.44	33613.17	31840.13	0.09	-5.19	-5.57	
APRIL	2748.22	15503.80	202.84	7441.01	7479.18	33375.05	33335.44	31696.62	-0.12	-5.03	-5.17	
MAY	4608.06	8877.75	134.35	4551.17	13786.94	31958.27	32419.61	30999.29	1.42	-3.00	-4.58	
JUNE	3844.97	7536.67	1775.05	3123.56	10431.70	26711.95	26611.89	26416.24	-0.38	-1.11	-0.74	
JULY	746.11	787.09	1023.86	8528.55	18266.58	29372.19	29372.21	28898.74	0.00	-1.61	-1.64	
AUGUST	488.03	8169.50	298.36	3309.55	14858.60	27124.04	27523.54	26819.63	1.45	-1.12	-2.62	
SEPTEMBER	1345.18	7997.86	1527.74	1865.11	8845.14	21581.03	21612.33	20863.67	0.14	-3.32	-3.59	
OCTOBER	1300.78	11619.05	311.99	560.82	4920.75	18713.39	18442.00	18155.96	-1.47	-2.98	-1.58	
NOVEMBER	2390.22	480.61	179.15	3198.88	13633.31	19882.17	20039.28	19255.80	0.78	-3.15	-4.07	
DECEMBER	5581.95	3057.72	12323.80	596.94	1788.97	23349.38	22766.12	22518.45	-2.56	-3.56	-1.10	
ANNUAL	38442.61	80213.09	42497.49	42846.40	121252.30	325251.89	324863.83	313837.38	-0.12	-3.51	-3.51	

APPENDIX E-1

# ANNUAL REPORT

## 2013

### ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

APPENDIX E-2

Month January	Year 2013	DATE	DAY	WELL 1		WELL 2		WELL 3		WELL 4		WELL 5		TREATED FLOW		PERCENTAGE RAW WATER WELL FIELD		PERCENTAGE TREATED WATER WELL FIELD		PERCENTAGE RAW WATER TREATED WATER	
				FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	RAW WATER WELL FIELD	TREATED WATER WELL FIELD	RAW WATER WELL FIELD	TREATED WATER WELL FIELD	RAW WATER TREATED WATER	
1	Tuesday	215.89	0.17	530.73	0.00	0.06	746.85	790.96	696.46	-7.24	5.91	11.95									
2	Wednesday	244.72	24.50	593.51	4.98	10.55	878.26	731.85	819.96	-7.11	-16.67	-12.04									
3	Thursday	196.29	0.17	500.66	7.96	16.98	722.06	743.18	681.23	-5.99	2.92	8.34									
4	Friday	243.00	0.17	598.68	0.00	0.17	842.02	721.12	783.86	-7.42	-14.36	-8.70									
5	Saturday	228.55	0.17	564.50	0.00	0.09	793.31	784.82	781.23	-1.55	-1.07	0.46									
6	Sunday	253.59	0.17	625.26	0.00	0.10	879.12	820.76	819.23	-7.31	-6.84	0.19									
7	Monday	32.05	423.66	78.17	211.40	9.97	755.25	738.00	752.39	-0.38	-2.28	-1.95									
8	Tuesday	0.04	369.61	0.01	234.31	99.50	703.47	729.50	656.23	-7.20	3.70	10.04									
9	Wednesday	0.04	409.05	0.05	206.54	226.01	841.69	727.40	825.33	-1.98	-13.58	-13.46									
10	Thursday	0.05	507.39	0.00	255.04	0.19	762.67	741.14	768.71	0.79	-2.82	-3.72									
11	Friday	0.04	436.07	0.04	220.90	44.80	701.85	716.18	700.27	-0.23	2.04	2.22									
12	Saturday	0.04	595.09	0.01	298.93	0.19	894.26	820.01	901.42	0.79	-8.30	-9.93									
13	Sunday	10.20	561.61	0.05	267.55	53.98	893.39	818.99	895.16	0.20	-8.33	-9.30									
14	Monday	0.03	403.39	49.08	228.67	53.76	734.93	751.93	757.48	2.98	2.31	-0.74									
15	Tuesday	0.04	777.56	0.00	391.51	0.10	1169.21	844.23	1185.79	1.40	-27.79	-40.46									
16	Wednesday	0.03	511.41	0.00	257.18	0.14	768.76	751.72	761.66	-0.93	-2.22	-1.32									
17	Thursday	0.03	844.21	0.00	424.49	0.08	1268.81	1187.33	1227.22	-3.39	-6.42	-3.36									
18	Friday	0.01	624.71	0.00	315.43	0.07	940.22	800.16	910.32	-3.28	-14.90	-13.77									
19	Saturday	0.00	534.13	0.00	269.13	0.02	803.28	842.02	796.15	-0.90	4.82	5.45									
20	Sunday	0.00	643.02	0.00	324.35	0.10	967.47	888.06	943.91	-2.50	-8.21	-6.29									
21	Monday	8.43	1087.06	26.13	546.48	20.54	1688.64	1619.12	1677.26	-0.68	-4.12	-3.59									
22	Tuesday	8.96	1304.46	0.00	654.71	0.00	1968.13	1862.15	1960.07	-0.41	-5.38	-5.26									
23	Wednesday	0.00	1183.72	635.92	224.85	19.44	2044.49	1899.45	2133.15	4.16	-7.09	-12.30									
24	Thursday	0.00	971.74	303.12	306.28	0.10	1581.24	1475.36	1610.49	1.82	-6.70	-9.16									
25	Friday	0.00	596.55	0.00	299.84	0.01	896.40	865.92	884.83	-1.31	-3.40	-2.18									
26	Saturday	5.38	567.07	10.68	285.06	0.01	868.20	886.25	879.34	1.27	2.08	0.78									
27	Sunday	299.60	23.36	753.09	7.45	9.35	1092.85	904.77	1030.08	-6.09	-17.21	-13.85									
28	Monday	200.22	9.88	525.27	20.85	43.90	800.12	825.30	761.61	-5.06	3.15	7.72									
29	Tuesday	192.79	32.71	32.01	16.17	582.62	856.30	863.51	851.92	-0.51	0.84	1.34									
30	Wednesday	248.84	0.17	0.00	0.00	733.61	982.62	881.58	963.44	-1.99	-10.28	-9.29									
31	Thursday	237.94	0.17	0.00	0.00	704.32	942.43	886.65	928.31	-1.52	-5.92	-4.70									
<b>TOTALS</b>				<b>2626.80</b>	<b>13443.15</b>	<b>5826.97</b>	<b>6280.06</b>	<b>2611.32</b>	<b>30788.30</b>	<b>30344.51</b>	<b>-1.46</b>	<b>-6.07</b>	<b>-4.93</b>								

# ANNUAL REPORT

## 2013

### ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

APPENDIX E-3

Month	Year	DATE	DAY	WELL 1		WELL 2		WELL 3		WELL 4		WELL 5		WELL FIELD		RAW FLOW	TREATED FLOW	PERCENTAGE TREATED WATER		PERCENTAGE RAW WATER	
				FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	WELL FIELD	WELL FIELD			WELL FIELD	WELL FIELD	WELL FIELD	WELL FIELD
February	2013	1	Friday	218.29	0.17	0.00	0.00	0.00	0.00	0.00	0.00	645.95	864.41	864.41	864.40	872.91	0.00	0.98	0.00	0.97	
		2	Saturday	256.43	0.17	0.00	0.00	0.00	0.00	0.00	758.06	1014.66	1014.66	1014.66	1014.66	962.96	0.00	-5.10	0.00	-5.37	
		3	Sunday	264.65	18.78	0.00	0.00	0.00	0.00	0.00	764.36	1047.79	1047.79	1047.79	1047.79	982.02	0.00	-6.28	0.00	-6.70	
		4	Monday	226.73	0.17	42.47	22.00	0.00	0.00	0.00	667.63	959.00	959.00	959.00	959.00	918.19	0.03	-4.26	0.03	-4.47	
		5	Tuesday	250.36	0.17	0.00	0.00	0.00	0.00	0.00	739.74	990.27	990.27	990.27	990.27	926.49	0.00	-6.44	0.00	-6.89	
		6	Wednesday	45.02	521.84	0.00	262.48	0.00	0.00	0.00	132.97	962.31	962.31	962.31	962.31	947.24	0.00	-1.57	0.00	-1.59	
		7	Thursday	0.00	608.13	0.02	306.29	0.02	0.00	0.00	64.84	979.28	979.28	979.28	979.28	960.55	0.00	-1.91	0.00	-1.95	
		8	Friday	0.00	99.11	0.50	321.94	0.50	0.00	0.00	536.21	957.76	957.76	957.76	957.76	934.51	0.00	-2.43	0.00	-2.49	
		9	Saturday	0.06	0.17	0.55	379.72	0.55	0.00	0.00	757.00	1137.50	1137.50	1137.50	1137.50	1015.50	0.00	-10.73	0.00	-12.01	
		10	Sunday	0.13	18.56	0.59	331.15	0.59	0.00	0.00	659.76	991.80	991.80	991.80	991.80	1013.89	0.00	2.23	0.00	2.18	
		11	Monday	6.02	0.17	54.16	316.17	54.16	0.00	0.00	631.36	1026.27	1026.27	1026.27	1026.27	957.32	-3.01	-6.72	-3.01	-4.07	
		12	Tuesday	0.13	0.17	0.55	319.64	0.55	0.00	0.00	636.69	957.18	957.18	957.18	957.18	946.51	0.00	-1.11	0.00	-1.13	
		13	Wednesday	0.12	0.17	0.48	348.82	0.48	0.00	0.00	694.81	1044.40	1044.40	1044.40	1044.40	963.89	0.00	-7.71	0.00	-8.35	
		14	Thursday	267.47	0.17	661.42	33.48	661.42	0.00	0.00	67.14	1029.68	1029.68	1029.68	1029.68	975.37	0.00	-5.27	0.00	-5.57	
		15	Friday	296.23	0.17	738.79	0.00	738.79	0.00	0.00	0.16	1037.35	1037.35	1037.35	1037.35	941.71	0.00	-9.22	0.00	-10.15	
		16	Saturday	302.15	0.17	749.42	0.00	749.42	0.00	0.00	0.13	1051.87	1051.87	1051.87	1051.87	1022.06	0.00	-2.83	0.00	-2.92	
		17	Sunday	335.32	0.17	830.33	0.00	830.33	0.00	0.00	0.09	1165.91	1165.91	1165.91	1165.91	1025.96	0.00	-12.00	0.00	-13.64	
		18	Monday	287.02	22.06	693.42	0.00	693.42	0.00	0.00	0.06	1002.56	1002.56	1002.56	1002.56	1017.04	0.00	1.44	0.00	1.42	
		19	Tuesday	291.80	0.17	765.79	23.58	765.79	23.58	0.00	22.83	1104.17	1104.17	1104.17	1104.17	958.46	0.00	-13.20	0.00	-15.20	
		20	Wednesday	271.34	0.17	671.05	0.00	671.05	0.00	0.00	0.11	942.67	942.67	942.67	942.67	972.48	0.00	3.16	0.00	3.07	
		21	Thursday	255.67	0.17	0.03	0.00	0.03	0.00	0.00	753.83	1009.70	1009.70	1009.70	1009.70	960.30	0.00	-4.89	0.00	-5.15	
		22	Friday	249.11	0.17	0.00	0.00	0.00	0.00	0.00	735.63	984.91	984.91	984.91	984.91	923.48	0.00	-6.24	0.00	-6.65	
		23	Saturday	264.80	0.17	0.00	0.00	0.00	0.00	0.00	781.90	1046.87	1046.87	1046.87	1046.87	997.44	0.00	-4.72	0.00	-4.95	
		24	Sunday	360.38	0.17	0.00	0.00	0.00	0.00	0.00	1064.52	1425.07	1425.07	1425.07	1425.07	1291.96	0.00	-9.34	0.00	-10.30	
		25	Monday	258.22	0.17	0.00	0.00	0.00	0.00	0.00	763.91	1022.30	1022.30	1022.30	1022.30	993.96	0.00	-2.77	0.00	-2.85	
		26	Tuesday	229.92	21.14	34.29	17.56	34.29	17.56	0.00	996.82	996.82	996.82	996.82	996.82	974.83	-0.01	-2.21	-0.01	-2.24	
		27	Wednesday	264.16	0.17	0.00	0.00	0.00	0.00	0.00	780.62	1044.95	1044.95	1044.95	1044.95	997.55	0.00	-4.53	0.00	-4.74	
		28	Thursday	256.86	0.17	0.00	0.00	0.00	0.00	0.00	759.19	1016.22	1016.22	1016.22	1016.22	998.75	0.00	-1.72	0.00	-1.75	
		TOTALS		5460.39	1313.19	5243.86	2682.83	5243.86	2682.83	14113.41	28813.68	28763.73	27453.43	27453.43	27453.43	27453.43	-0.10	-4.72	-0.10	-4.85	



# ANNUAL REPORT 2013

## ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

APPENDIX E-4

Month March	Year 2013	DAY	WELL 1	WELL 2	WELL 3	WELL 4	WELL 5	WELL FIELD	RAW	TREATED	PERCENTAGE	PERCENTAGE	PERCENTAGE
			FLOW m3	FLOW m3	FLOW m3	FLOW m3	FLOW m3	FLOW m3	RAW WATER WELL FIELD	RAW WATER WELL FIELD	TREATED WATER WELL FIELD	TREATED WATER WELL FIELD	RAW WATER WELL FIELD
1	Friday	242.00	0.17	0.02	114.06	716.91	1073.16	1104.00	998.81	2.79	-6.93	-10.53	
2	Saturday	253.25	0.17	0.01	63.01	746.62	1063.06	1063.06	1041.63	0.00	-2.02	-2.06	
3	Sunday	274.78	0.17	0.00	0.00	812.44	1087.39	1087.38	1031.40	0.00	-5.15	-5.43	
4	Monday	225.36	31.91	23.55	11.97	662.40	955.19	955.18	937.09	0.00	-1.89	-1.93	
5	Tuesday	256.45	0.17	0.00	0.00	759.69	1016.31	1016.31	961.37	0.00	-5.41	-5.71	
6	Wednesday	257.47	0.17	0.00	0.00	758.30	1015.94	1015.94	940.41	0.00	-7.43	-8.03	
7	Thursday	230.18	0.17	0.00	0.00	678.81	909.16	909.16	948.80	0.00	4.36	4.18	
8	Friday	225.94	0.17	475.53	223.71	98.74	1024.09	1024.08	912.92	0.00	-10.86	-12.18	
9	Saturday	289.26	0.17	715.53	0.00	0.14	1005.10	1005.10	984.82	0.00	-2.02	-2.06	
10	Sunday	305.21	0.17	753.40	0.00	0.14	1058.92	1058.91	973.92	0.00	-8.03	-8.73	
11	Monday	262.04	45.45	670.77	24.27	18.22	1020.75	1020.74	936.13	0.00	-8.29	-9.04	
12	Tuesday	237.46	38.92	590.57	18.19	38.69	923.83	923.83	923.74	0.00	-0.01	-0.01	
13	Wednesday	262.71	46.09	650.00	31.03	38.53	1028.36	1028.35	923.17	0.00	-10.23	-11.39	
14	Thursday	314.76	0.17	609.05	38.88	65.58	1028.44	1028.43	930.25	0.00	-9.55	-10.55	
15	Friday	346.79	0.17	859.15	0.00	0.14	1206.25	1206.25	1132.59	0.00	-6.11	-6.50	
16	Saturday	406.45	0.17	1007.44	0.00	0.11	1414.17	1414.16	1323.59	0.00	-6.41	-6.84	
17	Sunday	421.76	0.17	1046.33	0.00	0.10	1468.36	1468.35	1383.59	0.00	-5.77	-6.13	
18	Monday	304.84	0.17	822.02	36.84	34.13	1198.00	1204.94	1201.54	0.58	0.30	-0.28	
19	Tuesday	322.43	7.11	800.24	0.00	0.13	1129.91	1122.97	977.54	-0.62	-13.49	-14.88	
20	Wednesday	288.40	0.17	713.12	0.00	0.16	1001.85	1001.84	1031.75	0.00	2.98	2.90	
21	Thursday	349.07	0.17	866.51	0.00	0.10	1215.85	1215.85	1091.70	0.00	-10.21	-11.37	
22	Friday	302.07	0.17	745.60	0.00	0.07	1047.91	1047.91	993.48	0.00	-5.19	-5.48	
23	Saturday	319.05	0.17	791.62	0.00	0.08	1110.92	1110.92	1018.14	0.00	-8.35	-9.11	
24	Sunday	327.56	17.91	816.35	4.48	0.51	1166.81	1166.81	1058.76	0.00	-9.26	-10.21	
25	Monday	273.32	0.17	692.10	28.59	10.78	1004.96	1004.96	990.27	0.00	-1.46	-1.48	
26	Tuesday	0.02	541.28	0.03	0.01	541.40	1082.74	1082.74	999.12	0.00	-7.72	-8.37	
27	Wednesday	0.02	540.44	0.00	0.00	541.09	1081.55	1081.56	1007.06	0.00	-6.89	-7.40	
28	Thursday	0.03	153.86	0.24	112.88	750.84	1017.85	1017.84	985.92	0.00	-3.14	-3.24	
29	Friday	0.02	0.17	0.05	0.00	1050.86	1051.10	1051.10	1067.33	0.00	1.54	1.52	
30	Saturday	0.01	0.17	0.14	0.00	1091.12	1091.44	1091.43	1085.65	0.00	-0.53	-0.53	
31	Sunday	3.19	0.16	0.15	0.00	1079.57	1083.07	1083.07	1047.64	0.00	-3.27	-3.38	
		<b>TOTALS</b>	7301.90	1426.70	13649.92	707.92	10496.40	33582.44	33613.17	0.09	-5.19	-5.57	



# ANNUAL REPORT

## 2013

### ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

APPENDIX E-6

Month May	Year 2013	Day	WELL 1		WELL 2		WELL 3		WELL 4		WELL 5		WELL FIELD FLOW m3	RAW FLOW m3	TREATED FLOW m3	PERCENTAGE RAW WATER		PERCENTAGE TREATED WATER	
			FLOW m3		FLOW m3		FLOW m3		FLOW m3		WELL FIELD					WELL FIELD		WELL FIELD	
1	Wednesday	0.02	700.62	0.00	353.43	0.00	1054.07	1046.08	1009.30	-0.76	-4.25	-3.64							
2	Thursday	0.02	674.34	0.00	339.13	0.00	1013.49	1019.75	1044.75	0.61	3.08	2.39							
3	Friday	0.02	774.87	0.00	390.20	0.00	1165.09	1158.25	1036.28	-0.59	-11.06	-11.77							
4	Saturday	0.03	785.41	0.00	396.30	0.00	1181.74	1199.79	1110.45	1.50	-6.03	-8.05							
5	Sunday	4.31	760.50	10.77	382.36	4.26	1162.20	1169.71	1154.00	0.64	-0.71	-1.36							
6	Monday	0.03	727.21	11.98	373.82	8.68	1121.72	1135.50	1065.55	1.21	-5.01	-6.56							
7	Tuesday	7.94	794.28	0.00	380.70	0.01	1182.93	1197.53	1074.87	1.22	-9.13	-11.41							
8	Wednesday	0.05	692.56	0.00	348.68	0.00	1041.29	1075.21	1067.85	3.15	2.55	-0.69							
9	Thursday	0.03	654.03	26.37	344.54	27.56	1052.53	1079.64	1029.80	2.51	-2.16	-4.84							
10	Friday	0.02	710.01	0.01	358.27	0.10	1068.41	1092.59	995.77	2.21	-6.80	-9.72							
11	Saturday	0.02	726.76	0.00	365.66	0.09	1092.53	1133.61	1078.00	3.62	-1.33	-5.16							
12	Sunday	3.84	800.47	0.00	404.14	0.10	1208.55	1253.97	1093.33	3.62	-9.53	-14.69							
13	Monday	166.56	2.87	37.83	81.04	666.08	974.38	994.57	1040.55	2.03	6.79	4.42							
14	Tuesday	274.63	0.17	5.77	1.06	814.45	1096.08	1105.91	1045.71	0.89	-4.60	-5.76							
15	Wednesday	283.67	0.17	0.00	0.00	840.76	1124.60	1142.59	1057.24	1.57	-5.99	-8.07							
16	Thursday	270.11	0.17	0.04	8.79	798.43	1077.54	1079.03	1076.41	0.14	-0.10	-0.24							
17	Friday	258.12	28.32	12.94	7.03	785.30	1091.71	1104.01	1082.96	1.11	-0.80	-1.94							
18	Saturday	275.46	0.17	0.00	0.00	814.92	1090.55	1108.75	1101.73	1.64	1.03	-0.64							
19	Sunday	291.31	0.22	0.00	0.00	859.84	1151.37	1162.72	1088.80	0.98	-5.43	-6.79							
20	Monday	298.88	18.88	7.37	4.14	881.94	1211.21	1232.85	1143.25	1.76	-5.61	-7.84							
21	Tuesday	201.38	0.17	0.06	0.09	596.89	798.59	814.47	855.95	1.95	7.18	4.85							
22	Wednesday	206.22	0.17	0.00	0.00	608.44	814.83	825.83	796.18	1.33	-2.29	-3.72							
23	Thursday	214.73	0.17	0.00	0.00	634.81	849.71	863.11	782.69	1.55	-7.89	-10.27							
24	Friday	205.72	0.17	0.00	0.00	608.02	813.91	823.77	766.58	1.20	-5.82	-7.46							
25	Saturday	202.18	0.17	0.00	0.00	599.28	801.63	816.44	852.23	1.81	6.31	4.20							
26	Sunday	249.98	0.17	0.00	0.00	736.32	986.47	1001.10	904.87	1.46	-8.27	-10.63							
27	Monday	202.14	23.94	21.21	11.79	630.92	890.00	900.83	850.94	1.20	-4.39	-5.86							
28	Tuesday	244.57	0.17	0.00	0.00	722.40	967.14	970.70	990.01	0.37	2.36	1.95							
29	Wednesday	230.77	0.17	0.00	0.00	681.97	912.91	921.83	960.22	0.97	5.18	4.00							
30	Thursday	252.33	0.21	0.00	0.00	746.14	998.68	1009.37	947.48	1.06	-5.13	-6.53							
31	Friday	242.97	0.21	0.00	0.00	719.23	962.41	980.10	895.54	1.80	-6.95	-9.44							
<b>TOTALS</b>		4608.06	8877.75	134.35	4551.17	13786.94	31958.27	32419.61	30999.29	1.42	-3.00	-4.58							

# ANNUAL REPORT

## 2013

# ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

APPENDIX E-7

Month June	Year 2013	Day	WELL 1	WELL 2	WELL 3	WELL 4	WELL 5	WELL FIELD	RAW	TREATED	PERCENTAGE	PERCENTAGE	PERCENTAGE	PERCENTAGE
			FLOW	FLOW	FLOW	FLOW	FLOW	FLOW	FLOW	FLOW	FLOW	RAW WATER	TREATED WATER	RAW WATER
DATE			m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>
1	Saturday	250.47	0.17	0.00	0.00	0.00	841.33	1091.97	991.96	964.89	-10.08	-11.64	-2.81	
2	Sunday	200.32	12.52	3.14	1.65	610.64	828.27	828.27	828.26	847.72	0.00	2.35	2.30	
3	Monday	193.31	0.17	5.09	2.92	578.76	780.25	780.25	780.25	780.25	0.00	0.09	0.09	
4	Tuesday	208.41	0.17	0.00	0.00	614.98	823.56	823.56	823.56	813.77	0.00	-1.19	-1.20	
5	Wednesday	238.02	0.17	0.00	0.00	703.77	941.96	941.96	941.96	897.75	0.00	-4.69	-4.92	
6	Thursday	236.41	0.17	0.00	0.00	697.05	933.63	933.63	933.63	890.71	0.00	-4.60	-4.82	
7	Friday	221.51	0.17	0.00	0.00	654.41	876.09	876.09	876.09	869.65	0.00	-0.74	-0.74	
8	Saturday	260.90	0.17	0.00	0.00	771.05	1032.12	1032.12	1032.11	963.40	0.00	-6.86	-7.13	
9	Sunday	220.00	0.17	0.00	0.00	651.63	871.80	871.80	871.79	941.93	0.00	8.04	7.45	
10	Monday	197.84	28.91	13.97	7.75	617.12	865.59	865.59	865.59	830.49	0.00	-4.06	-4.23	
11	Tuesday	202.40	0.22	0.00	0.00	592.81	795.43	795.43	795.43	795.24	0.00	-0.02	-0.02	
12	Wednesday	238.43	0.21	0.00	0.00	706.98	945.62	945.62	945.63	818.72	0.00	-13.42	-15.50	
13	Thursday	200.12	0.17	0.00	0.00	592.22	792.51	792.51	792.51	840.08	0.00	6.00	5.66	
14	Friday	217.27	0.17	0.00	0.00	638.33	855.77	855.77	855.76	841.01	0.00	-1.72	-1.75	
15	Saturday	221.83	0.18	0.00	0.00	656.87	878.88	878.88	878.87	819.35	0.00	-6.77	-7.26	
16	Sunday	0.04	514.18	0.00	259.46	0.00	0.00	773.68	773.68	819.26	0.00	5.89	5.56	
17	Monday	6.42	450.28	81.38	269.91	88.06	896.05	896.05	896.05	837.04	0.00	-6.59	-7.05	
18	Tuesday	0.03	600.27	0.05	292.51	34.08	926.94	926.94	926.94	868.30	0.00	-6.33	-6.75	
19	Wednesday	0.05	518.55	43.59	261.60	45.11	868.90	868.90	868.91	864.07	0.00	-0.56	-0.56	
20	Thursday	34.16	414.38	0.40	209.47	201.44	859.85	859.85	859.85	868.48	0.00	1.00	0.99	
21	Friday	0.02	615.75	0.00	310.24	0.00	926.01	926.01	926.02	812.58	0.00	-12.25	-13.96	
22	Saturday	0.01	348.79	0.00	325.30	0.06	674.16	674.16	674.17	1187.92	0.00	76.21	43.25	
23	Sunday	0.02	832.44	0.00	0.00	0.00	832.46	832.46	832.46	846.41	0.00	1.68	1.65	
24	Monday	5.90	795.44	20.38	232.35	11.88	1065.95	1065.95	1065.95	991.07	0.00	-7.02	-7.56	
25	Tuesday	0.02	677.82	0.00	342.70	0.00	1020.54	1020.54	1020.53	1021.25	0.00	0.07	0.07	
26	Wednesday	10.34	581.17	36.07	309.97	23.67	961.22	961.22	961.22	848.67	0.00	-11.71	-13.26	
27	Thursday	0.04	516.05	0.00	260.55	0.00	776.64	776.64	776.63	839.67	0.00	8.12	7.51	
28	Friday	0.01	490.97	270.11	37.18	99.09	897.36	897.36	897.36	865.43	0.00	-3.56	-3.69	
29	Saturday	216.06	136.62	646.18	0.00	0.18	999.04	999.04	999.03	870.21	0.00	-12.90	-14.80	
30	Sunday	264.61	0.22	654.69	0.00	0.18	919.70	919.70	919.69	960.20	0.00	4.40	4.22	
<b>TOTALS</b>			<b>3844.97</b>	<b>7536.67</b>	<b>1775.05</b>	<b>3123.56</b>	<b>10431.70</b>	<b>26711.95</b>	<b>26611.89</b>	<b>26416.24</b>	<b>-0.38</b>	<b>-1.11</b>	<b>-0.74</b>	



# ANNUAL REPORT

## 2013

### ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

APPENDIX E-8

Month July	Year 2013	WELL 1		WELL 2		WELL 3		WELL 4		WELL 5		WELL FLOW		RAW FLOW m3	TREATED FLOW m3	PERCENTAGE RAW WATER WELL FIELD		PERCENTAGE TREATED WATER WELL FIELD		PERCENTAGE RAW WATER TREATED WATER
		FLOW m3	WELL FLOW m3	FLOW m3	WELL FLOW m3	FLOW m3	WELL FLOW m3	FLOW m3	WELL FLOW m3	PERCENTAGE RAW WATER WELL FIELD	PERCENTAGE TREATED WATER WELL FIELD	PERCENTAGE RAW WATER WELL FIELD	PERCENTAGE TREATED WATER WELL FIELD							
1	Monday	307.39	22.93	762.83	8.27	14.61	1116.03	1116.04	999.72	0.00	0.00	-10.42	-11.64							
2	Tuesday	317.04	47.71	58.75	34.96	581.13	1039.59	1039.59	1025.79	0.00	0.00	-1.33	-1.35							
3	Wednesday	34.61	67.40	0.49	345.36	696.96	1144.82	1144.83	1092.44	0.00	0.00	-4.58	-4.80							
4	Thursday	0.04	0.23	0.48	325.08	647.01	972.84	972.84	997.15	0.00	0.00	2.50	2.44							
5	Friday	0.03	0.22	0.49	308.54	614.95	924.23	924.22	847.29	0.00	0.00	-8.32	-9.08							
6	Saturday	0.04	0.21	0.43	256.82	511.86	769.36	769.37	822.34	0.00	0.00	6.89	6.44							
7	Sunday	0.05	0.23	0.41	245.95	489.84	736.48	736.49	761.38	0.00	0.00	3.38	3.27							
8	Monday	5.92	19.22	14.31	292.30	581.46	913.21	913.22	970.10	0.00	0.00	6.23	5.86							
9	Tuesday	0.02	0.20	0.36	245.71	489.27	735.56	735.55	733.15	0.00	0.00	-0.33	-0.33							
10	Wednesday	14.88	48.57	48.36	207.22	405.34	724.37	724.38	724.37	0.00	0.00	0.00	0.00							
11	Thursday	20.95	0.22	69.52	237.88	473.36	801.93	801.93	765.24	0.00	0.00	-4.58	-4.79							
12	Friday	0.03	0.22	0.55	258.76	515.12	774.68	774.68	773.40	0.00	0.00	-0.17	-0.17							
13	Saturday	0.03	0.21	0.39	259.65	516.96	777.24	777.24	791.92	0.00	0.00	1.89	1.85							
14	Sunday	7.11	21.78	0.46	274.32	546.11	849.77	849.77	850.75	0.00	0.00	0.11	0.12							
15	Monday	0.01	0.19	12.10	483.75	964.62	1460.67	1460.67	1441.40	0.00	0.00	-1.32	-1.34							
16	Tuesday	0.04	0.19	0.40	610.96	1219.19	1830.78	1830.78	1775.27	0.00	0.00	-3.03	-3.13							
17	Wednesday	0.03	0.21	0.37	519.12	1036.31	1556.04	1556.04	1554.14	0.00	0.00	-0.12	-0.12							
18	Thursday	0.02	0.20	0.48	308.58	614.40	923.68	923.68	865.14	0.00	0.00	-6.34	-6.77							
19	Friday	0.04	0.22	0.40	256.24	510.27	767.17	767.17	813.20	0.00	0.00	6.00	5.66							
20	Saturday	0.06	0.26	0.45	304.44	606.24	911.45	911.46	814.82	0.00	0.00	-10.60	-11.86							
21	Sunday	0.06	0.27	0.38	263.09	523.84	787.64	787.64	862.37	0.00	0.00	9.49	8.67							
22	Monday	10.02	31.70	24.27	259.00	505.39	830.38	830.38	805.18	0.00	0.00	-3.03	-3.13							
23	Tuesday	0.05	0.26	0.21	196.75	705.40	902.67	902.66	802.19	0.00	0.00	-11.13	-12.52							
24	Wednesday	0.04	0.24	0.47	274.82	546.78	822.35	822.35	882.74	0.00	0.00	7.34	6.84							
25	Thursday	0.08	0.23	0.53	299.62	596.45	896.87	896.87	817.82	0.00	0.00	-8.81	-9.67							
26	Friday	0.04	0.25	0.42	290.69	579.13	870.57	870.58	836.85	0.00	0.00	-3.87	-4.03							
27	Saturday	0.05	0.24	0.46	281.96	561.02	843.73	843.73	889.37	0.00	0.00	5.41	5.13							
28	Sunday	0.04	0.23	0.45	325.37	648.18	974.27	974.26	930.23	0.00	0.00	-4.52	-4.73							
29	Monday	27.35	92.42	24.18	247.01	490.53	881.49	881.48	880.51	0.00	0.00	-0.11	-0.11							
30	Tuesday	0.02	0.22	0.44	303.32	604.19	908.19	908.21	849.28	0.00	0.00	-6.49	-6.94							
31	Wednesday	0.02	430.41	0.02	3.01	490.66	924.12	924.12	923.19	0.00	0.00	-0.10	-0.10							
TOTALS		746.11	787.09	1023.86	8528.55	18286.58	29372.19	29372.21	28898.74	0.00	0.00	-1.61	-1.64							

# ANNUAL REPORT 2013 ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

## APPENDIX E-9

Month August	Year 2013	DAY	WELL 1		WELL 2		WELL 3		WELL 4		WELL 5		WELL FIELD		RAW FLOW		TREATED FLOW		PERCENTAGE RAW WATER		PERCENTAGE TREATED WATER	
			FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	WELL FIELD	WELL FIELD	WELL FIELD	WELL FIELD	WELL FIELD	WELL FIELD
1	Thursday	0.02	617.46	0.00	0.00	0.00	304.20	921.68	921.68	862.34	862.34	0.00	0.00	-6.44	0.00	0.00	0.00	-6.88	0.00	-6.88	0.00	-6.88
2	Friday	0.02	904.53	0.00	0.00	0.00	0.00	904.55	904.55	853.87	853.87	0.00	0.00	-5.60	0.00	0.00	0.00	-5.94	0.00	-5.94	0.00	-5.94
3	Saturday	0.30	927.13	0.00	0.00	0.00	0.00	927.43	927.43	880.39	880.39	0.00	0.00	-5.07	-0.03	0.00	0.00	-5.31	-0.03	-5.31	0.00	-5.31
4	Sunday	0.03	864.46	0.00	0.00	0.00	0.00	864.49	864.49	866.08	866.08	0.00	0.00	0.18	0.00	0.00	0.00	0.18	0.00	0.18	0.00	0.18
5	Monday	6.37	907.07	0.00	0.00	0.00	0.00	913.44	913.44	907.28	907.28	0.00	0.00	-0.67	0.00	0.00	0.00	-0.68	0.00	-0.68	0.00	-0.68
6	Tuesday	36.31	796.49	0.00	0.00	0.00	0.00	832.80	832.80	858.12	858.12	0.00	0.00	3.04	0.00	0.00	0.00	2.95	0.00	2.95	0.00	2.95
7	Wednesday	0.02	965.54	0.00	0.00	0.00	0.00	965.56	965.56	929.23	929.23	0.00	0.00	-3.76	0.00	0.00	0.00	-3.91	0.00	-3.91	0.00	-3.91
8	Thursday	27.14	166.09	53.93	7.59	649.16	903.91	903.91	903.92	884.66	884.66	649.16	903.91	-2.13	0.00	0.00	0.00	-2.18	0.00	-2.18	0.00	-2.18
9	Friday	66.06	0.22	0.36	271.90	676.13	1014.57	1014.57	1014.58	892.60	892.60	676.13	1014.57	-12.02	0.00	0.00	0.00	-13.67	0.00	-13.67	0.00	-13.67
10	Saturday	0.01	0.22	0.47	311.44	620.44	932.58	932.58	932.59	925.51	925.51	620.44	932.58	-0.76	0.00	0.00	0.00	-0.76	0.00	-0.76	0.00	-0.76
11	Sunday	0.01	0.22	0.44	314.98	626.98	942.63	942.63	942.63	936.34	936.34	626.98	942.63	-0.67	0.00	0.00	0.00	-0.67	0.00	-0.67	0.00	-0.67
12	Monday	6.41	18.16	100.19	245.34	503.20	873.30	873.30	873.29	882.11	882.11	503.20	873.30	1.01	0.00	0.00	0.00	1.00	0.00	1.00	0.00	1.00
13	Tuesday	0.04	0.24	0.44	310.02	617.91	928.65	928.65	928.65	870.50	870.50	617.91	928.65	-6.26	0.00	0.00	0.00	-6.68	0.00	-6.68	0.00	-6.68
14	Wednesday	0.02	109.39	111.16	211.52	420.85	852.94	852.94	852.94	880.49	880.49	420.85	852.94	3.23	0.00	0.00	0.00	3.13	0.00	3.13	0.00	3.13
15	Thursday	0.03	0.24	0.47	298.07	593.35	892.16	892.16	892.17	872.96	872.96	593.35	892.16	-2.15	0.00	0.00	0.00	-2.20	0.00	-2.20	0.00	-2.20
16	Friday	0.03	0.24	0.49	307.60	611.62	919.98	919.98	919.98	861.54	861.54	611.62	919.98	-6.35	0.00	0.00	0.00	-6.78	0.00	-6.78	0.00	-6.78
17	Saturday	0.03	0.23	0.41	323.83	644.94	969.44	969.44	969.44	985.36	985.36	644.94	969.44	1.64	0.00	0.00	0.00	1.61	0.00	1.61	0.00	1.61
18	Sunday	7.66	25.56	17.31	483.83	982.94	1527.30	1527.30	1527.29	1402.63	1402.63	982.94	1527.30	-8.16	0.00	0.00	0.00	-8.89	0.00	-8.89	0.00	-8.89
19	Monday	0.02	145.88	0.25	212.72	583.15	942.02	942.02	942.00	916.94	916.94	583.15	942.02	-2.66	0.00	0.00	0.00	-2.73	0.00	-2.73	0.00	-2.73
20	Tuesday	0.02	44.72	0.00	0.00	446.74	491.48	491.48	491.48	932.40	932.40	446.74	491.48	89.71	44.87	44.87	44.87	4.39	44.87	4.39	44.87	4.39
21	Wednesday	0.05	441.43	0.00	0.00	443.20	884.68	884.68	884.67	886.03	886.03	443.20	884.68	0.15	0.00	0.00	0.00	0.15	0.00	0.15	0.00	0.15
22	Thursday	0.02	430.18	0.00	0.00	432.31	862.51	862.51	862.51	781.66	781.66	432.31	862.51	-9.37	0.00	0.00	0.00	-10.34	0.00	-10.34	0.00	-10.34
23	Friday	0.01	355.11	0.00	0.00	357.39	712.51	712.51	712.51	763.49	763.49	357.39	712.51	7.15	0.00	0.00	0.00	6.68	0.00	6.68	0.00	6.68
24	Saturday	0.01	432.63	0.00	0.00	434.85	867.49	867.49	867.49	795.88	795.88	434.85	867.49	-8.25	0.00	0.00	0.00	-9.00	0.00	-9.00	0.00	-9.00
25	Sunday	209.06	14.84	12.36	0.68	638.00	874.94	874.94	874.95	853.88	853.88	638.00	874.94	-2.41	0.00	0.00	0.00	-2.47	0.00	-2.47	0.00	-2.47
26	Monday	128.16	0.19	0.03	0.13	707.12	835.63	835.63	835.62	789.02	789.02	707.12	835.63	-5.58	0.00	0.00	0.00	-5.91	0.00	-5.91	0.00	-5.91
27	Tuesday	0.01	0.19	0.00	0.00	758.32	758.52	758.52	758.52	814.35	814.35	758.32	758.52	7.36	-0.03	-0.03	-0.03	6.88	-0.03	6.88	0.00	6.88
28	Wednesday	0.02	0.20	0.00	0.00	786.08	786.30	786.30	786.29	723.40	723.40	786.08	786.30	-8.00	0.00	0.00	0.00	-8.69	0.00	-8.69	0.00	-8.69
29	Thursday	0.05	0.20	0.00	0.00	741.38	741.63	741.63	741.60	725.82	725.82	741.38	741.63	-2.13	0.00	0.00	0.00	-2.17	0.00	-2.17	0.00	-2.17
30	Friday	0.05	0.22	0.00	0.00	634.11	634.38	634.38	634.38	643.05	643.05	634.11	634.38	1.37	0.00	0.00	0.00	1.35	0.00	1.35	0.00	1.35
31	Saturday	0.04	0.22	0.05	0.00	644.23	644.54	644.54	644.54	641.70	641.70	644.23	644.54	-0.44	0.00	0.00	0.00	-0.44	0.00	-0.44	0.00	-0.44
TOTALS		488.03	8169.50	298.36	3309.55	14858.60	27124.04	27124.04	27523.54	26819.63	26819.63	14858.60	27124.04	1.45	1.45	1.45	1.45	-1.12	1.45	-1.12	1.45	-1.12



# ANNUAL REPORT

## 2013

### ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

APPENDIX E-11

Month October	Year 2013	Day	WELL 1	WELL 2	WELL 3	WELL 4	WELL 5	WELL FIELD		RAW FLOW m <sup>3</sup>	TREATED FLOW m <sup>3</sup>	PERCENTAGE RAW WATER WELL FIELD	PERCENTAGE TREATED WATER WELL FIELD	PERCENTAGE RAW WATER TREATED WATER
			FLOW m <sup>3</sup>	FLOW m <sup>3</sup>	FLOW m <sup>3</sup>	FLOW m <sup>3</sup>	FLOW m <sup>3</sup>	FLOW m <sup>3</sup>						
1	Tuesday	143.400	0.22	0.000	0.010	420.330	563.96	569.070	544.610	0.91	-3.43	-4.49		
2	Wednesday	142.010	0.2	0.000	0.000	418.220	560.43	567.870	542.600	1.33	-3.18	-4.66		
3	Thursday	141.380	0.2	0.000	0.000	413.290	554.87	555.890	540.260	0.18	-2.63	-2.89		
4	Friday	142.640	0.17	0.000	0.000	417.890	560.70	567.030	492.960	1.13	-12.08	-15.03		
5	Saturday	144.120	0.18	0.000	0.000	423.680	567.97	574.520	545.740	1.15	-3.91	-5.27		
6	Sunday	154.410	0.18	0.000	0.000	453.740	608.33	615.930	591.700	1.25	-2.73	-4.09		
7	Monday	112.640	18.83	13.230	9.290	338.340	492.33	495.920	512.820	0.73	4.16	3.30		
8	Tuesday	143.280	0.17	0.000	0.000	421.180	564.63	567.020	535.850	0.42	-5.10	-5.82		
9	Wednesday	89.430	110.78	82.540	54.410	220.500	557.66	556.320	593.110	-0.24	6.36	6.20		
10	Thursday	18.670	572.89	0.010	0.010	18.890	610.47	598.520	564.970	-1.96	-7.45	-5.94		
11	Friday	0.050	425.59	0.000	0.020	220.400	646.06	637.390	580.450	-1.34	-10.16	-9.81		
12	Saturday	0.030	656.71	0.000	0.000	0.000	656.74	637.000	638.320	-3.01	-2.80	0.21		
13	Sunday	0.040	590.42	0.000	0.000	0.000	595.32	517.470	596.150	-3.33	11.36	13.20		
14	Monday	8.430	569.49	40.160	0.020	47.050	637.53	621.080	634.730	-2.58	-0.44	2.15		
15	Tuesday	0.050	565.73	0.000	24.150	45.190	687.42	675.100	590.140	-1.79	-14.15	-14.40		
16	Wednesday	0.050	539.05	0.010	0.000	0.000	565.78	547.280	580.300	-3.27	2.57	5.69		
17	Thursday	0.050	610.65	0.000	0.000	0.000	539.11	522.610	568.650	-3.06	5.48	8.10		
18	Friday	0.060	651.34	0.000	0.000	0.000	610.70	591.050	537.970	-3.22	-11.91	-9.87		
19	Saturday	11.700	655.4	0.000	0.000	0.000	651.40	631.190	602.170	-3.10	-7.56	-4.82		
20	Sunday	3.800	453.08	33.820	21.370	27.250	667.10	646.760	631.110	-3.05	-5.39	-2.48		
21	Monday	0.040	615.03	0.000	0.000	0.000	539.32	524.130	566.130	-2.82	4.87	7.42		
22	Tuesday	0.030	636.42	0.000	0.000	0.000	615.07	595.830	585.900	-3.13	-4.74	-1.69		
23	Wednesday	0.030	453.65	0.110	0.000	0.000	636.45	615.740	587.740	-3.25	-7.65	-4.76		
24	Thursday	19.830	615.58	34.080	0.410	62.170	516.37	496.790	580.030	-3.79	12.33	14.35		
25	Friday	10.920	651.52	0.010	0.480	0.000	669.87	649.940	565.400	-2.99	-15.61	-14.95		
26	Saturday	0.030	650.62	0.000	0.000	0.000	664.59	643.670	650.340	-3.15	-2.14	1.03		
27	Sunday	13.540	531.26	23.670	15.260	12.570	596.30	578.720	619.220	-3.15	3.55	6.47		
28	Monday	0.020	508.06	83.790	0.090	92.450	684.41	680.620	593.270	-2.95	3.84	6.54		
29	Tuesday	0.040	0.17	0.250	212.230	421.080	633.77	646.830	640.800	-0.55	-13.32	-14.72		
30	Wednesday	0.040	0.17	0.310	223.060	444.400	667.98	684.560	668.770	2.06	1.11	-0.94		
31	Thursday	1300.78	11619.05	311.99	560.82	4920.75	18713.39	18442.00	18155.96	2.48	0.12	-2.36		
		TOTALS								-1.45	-2.98	-1.58		



# ANNUAL REPORT

## 2013

### ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

APPENDIX E-12

Month November	Year 2013	DATE	DAY	WELL 1		WELL 2		WELL 3		WELL 4		WELL 5		WELL FIELD		RAW FLOW m3	TREATED FLOW m3	PERCENTAGE RAW WATER		PERCENTAGE TREATED WATER	
				FLOW m3		FLOW m3		FLOW m3		FLOW m3		FLOW m3		WELL FIELD	FLOW			WELL FIELD	WELL FIELD	WELL FIELD	WELL FIELD
1		Friday	0.02	0.17	0.40	243.30	483.80	727.69	746.24	666.84	2.49	-8.36	-11.91								
2		Saturday	0.02	0.17	0.32	245.34	488.68	734.53	747.28	715.52	1.71	-2.59	-4.44								
3		Sunday	7.80	18.54	2.41	255.67	509.37	793.79	784.74	735.67	-1.15	-7.32	-6.67								
4		Monday	0.05	0.17	61.54	198.98	391.27	652.01	674.96	650.74	3.40	-0.19	-3.72								
5		Tuesday	0.08	0.17	0.31	220.79	440.00	661.35	678.59	673.34	2.54	1.81	-0.78								
6		Wednesday	0.07	0.17	0.30	228.82	455.63	684.99	703.59	606.29	2.64	-11.49	-16.05								
7		Thursday	0.06	0.17	0.36	202.42	402.73	605.74	624.95	629.02	3.07	3.84	0.65								
8		Friday	0.05	0.17	0.26	216.20	430.20	646.88	662.61	626.59	2.37	-3.14	-5.75								
9		Saturday	0.06	0.17	0.33	223.08	443.25	666.89	685.97	703.40	2.78	5.47	2.48								
10		Sunday	0.07	0.17	0.34	261.02	518.96	780.56	802.48	748.65	2.73	-4.09	-7.19								
11		Monday	8.20	18.83	43.43	229.22	452.81	752.49	774.56	719.34	2.85	-4.41	-7.68								
12		Tuesday	0.03	0.17	0.31	226.95	451.08	678.54	698.08	646.98	2.80	-4.65	-7.90								
13		Wednesday	0.03	0.17	0.32	236.52	470.86	707.90	729.77	655.68	3.00	-7.38	-11.30								
14		Thursday	13.31	37.13	30.31	187.42	372.86	641.03	651.03	600.82	1.54	-6.27	-8.36								
15		Friday	0.02	0.17	0.00	0.01	265.31	529.42	551.13	567.06	3.94	7.11	2.81								
16		Saturday	157.47	0.17	0.00	0.00	461.95	619.59	624.62	643.35	0.81	3.83	2.91								
17		Sunday	184.45	0.17	0.00	0.00	543.03	727.65	734.03	663.03	0.87	-8.88	-10.71								
18		Monday	84.24	22.05	18.46	11.13	393.65	519.53	519.53	586.44	0.00	12.88	11.41								
19		Tuesday	156.09	0.16	0.00	0.00	515.82	672.07	622.76	586.11	-7.92	-12.79	-6.25								
20		Wednesday	144.80	0.17	0.00	0.00	424.98	569.95	575.72	599.33	1.00	3.40	2.31								
21		Thursday	143.17	0.17	0.00	0.00	419.24	562.58	563.05	578.96	0.08	2.91	2.75								
22		Friday	156.57	92.13	0.00	0.00	398.18	646.88	645.65	575.84	-0.16	-10.98	-12.16								
23		Saturday	149.76	0.17	0.00	0.00	441.35	591.28	593.02	644.74	0.29	9.04	8.02								
24		Sunday	189.22	0.17	0.00	0.00	554.73	744.12	743.55	664.86	-0.08	-7.96	-8.57								
25		Monday	160.87	23.95	19.74	11.97	464.87	681.40	669.24	639.40	-1.82	-6.16	-4.87								
26		Tuesday	149.73	0.17	0.01	0.02	440.05	589.98	580.02	611.20	-1.72	3.60	5.10								
27		Wednesday	171.12	0.17	0.00	0.00	499.74	671.03	656.59	632.40	-2.20	-5.76	-3.83								
28		Thursday	170.62	0.17	0.00	0.00	502.25	673.04	664.72	624.85	-1.25	-7.16	-6.38								
29		Friday	148.92	0.17	0.00	0.00	437.02	586.11	577.14	590.30	-1.55	0.71	2.23								
30		Saturday	193.32	0.17	0.00	0.02	569.64	763.15	753.46	659.05	-1.29	-13.64	-14.33								
<b>TOTALS</b>				<b>2390.22</b>	<b>480.61</b>	<b>179.15</b>	<b>3196.88</b>	<b>13633.31</b>	<b>19882.17</b>	<b>20039.28</b>	<b>19255.80</b>	<b>0.78</b>	<b>-3.15</b>	<b>-4.07</b>							

# ANNUAL REPORT 2013

## ACTUAL DAILY FLOWS & COMPLIANCE SHEET - WATER

Month DATE	Year DAY	WELL 1		WELL 2		WELL 3		WELL 4		WELL 5		WELL FIELD		RAW FLOW		TREATED FLOW		PERCENTAGE RAW WATER WELL FIELD		PERCENTAGE TREATED WATER WELL FIELD		PERCENTAGE RAW WATER TREATED WATER	
		FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	FLOW	m3	PERCENTAGE	PERCENTAGE	PERCENTAGE	PERCENTAGE	PERCENTAGE	PERCENTAGE
1	Sunday	160.51	0.17	0.00	0.00	0.00	0.00	0.00	0.00	470.96	631.64	620.50	712.47	-1.80	12.80	12.91							
2	Monday	165.18	22.35	22.02	13.66	22.02	13.66	22.02	13.66	517.33	740.54	725.31	634.19	-2.10	-14.36	-14.37							
3	Tuesday	181.75	0.17	333.39	0.18	333.39	0.18	333.39	0.18	116.61	632.10	600.45	637.58	-5.27	0.87	5.82							
4	Wednesday	157.67	0.17	387.44	0.05	387.44	0.05	387.44	0.05	118.45	683.78	646.22	649.73	-2.72	-2.12	0.54							
5	Thursday	236.40	0.17	582.10	0.09	582.10	0.09	582.10	0.09	0.00	818.76	771.77	671.95	-6.09	-17.93	-14.86							
6	Friday	181.19	0.17	447.87	0.05	447.87	0.05	447.87	0.05	0.00	629.28	594.76	670.71	-5.80	6.58	11.32							
7	Saturday	235.66	0.17	58.41	0.35	58.41	0.35	58.41	0.35	0.03	294.62	767.98	695.77	61.64	136.16	11.32							
8	Sunday	189.55	0.17	467.38	0.18	467.38	0.18	467.38	0.18	0.03	657.31	619.38	713.93	-6.12	8.61	-10.38							
9	Monday	176.21	14.38	480.47	30.02	480.47	30.02	480.47	30.02	51.09	752.17	715.52	664.00	-5.12	-11.72	-7.76							
10	Tuesday	168.03	54.24	413.79	53.73	413.79	53.73	413.79	53.73	60.90	750.69	727.69	664.46	-3.16	-11.49	-9.52							
11	Wednesday	165.51	37.31	407.57	26.51	407.57	26.51	407.57	26.51	42.91	679.81	653.77	665.49	-3.98	-2.11	1.76							
12	Thursday	152.80	72.49	374.69	0.05	374.69	0.05	374.69	0.05	81.21	681.24	660.60	667.37	-3.12	-2.04	1.01							
13	Friday	196.94	0.17	483.81	0.09	483.81	0.09	483.81	0.09	42.48	723.49	680.40	651.85	-6.33	-9.90	-4.38							
14	Saturday	202.28	0.17	499.16	0.04	499.16	0.04	499.16	0.04	39.70	741.35	711.23	714.83	-4.23	-3.58	0.50							
15	Sunday	197.52	44.89	484.60	34.76	484.60	34.76	484.60	34.76	2.13	763.90	726.19	746.01	-5.19	-2.34	2.66							
16	Monday	195.42	22.92	505.10	30.19	505.10	30.19	505.10	30.19	9.25	762.88	724.20	702.40	-5.34	-7.93	-3.10							
17	Tuesday	243.02	0.17	599.01	0.02	599.01	0.02	599.01	0.02	0.08	842.30	789.84	807.86	-6.64	-4.09	2.23							
18	Wednesday	417.92	0.17	1031.95	0.00	1031.95	0.00	1031.95	0.00	0.19	1450.23	1364.23	1324.67	-6.30	-8.66	-2.99							
19	Thursday	235.33	0.17	579.98	0.01	579.98	0.01	579.98	0.01	0.09	815.58	766.88	745.27	-6.35	-8.62	-2.90							
20	Friday	211.71	0.17	521.12	0.00	521.12	0.00	521.12	0.00	0.07	733.07	690.10	679.22	-6.23	-7.35	-1.60							
21	Saturday	219.96	0.17	542.28	0.02	542.28	0.02	542.28	0.02	0.10	762.53	717.98	741.73	-6.20	-2.73	3.20							
22	Sunday	239.82	0.17	590.67	0.02	590.67	0.02	590.67	0.02	1.95	832.63	782.42	756.26	-6.42	-9.17	-3.46							
23	Monday	197.13	84.43	477.48	11.88	477.48	11.88	477.48	11.88	22.14	793.06	753.98	701.73	-5.18	-11.52	-7.45							
24	Tuesday	140.91	40.76	347.67	85.67	347.67	85.67	347.67	85.67	92.17	707.18	688.61	735.06	-2.70	3.94	6.32							
25	Wednesday	232.07	0.17	568.78	0.02	568.78	0.02	568.78	0.02	0.07	801.11	747.53	684.26	-7.17	-14.59	-9.25							
26	Thursday	230.05	91.59	385.70	0.00	385.70	0.00	385.70	0.00	0.07	707.41	665.75	723.39	-6.26	2.26	7.97							
27	Friday	0.03	444.26	121.90	205.05	121.90	205.05	121.90	205.05	3.43	774.67	774.95	718.38	0.04	7.27	-7.87							
28	Saturday	0.04	672.20	0.00	89.28	0.00	89.28	0.00	89.28	0.00	761.52	748.32	750.20	-1.76	-1.49	0.25							
29	Sunday	0.04	876.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	876.45	840.29	775.56	-4.30	-11.51	-8.35							
30	Monday	16.48	533.02	30.28	14.94	30.28	14.94	30.28	14.94	115.48	710.20	684.53	738.90	-3.75	4.04	7.36							
31	Tuesday	234.82	43.75	579.18	0.08	579.18	0.08	579.18	0.08	0.05	857.88	804.74	773.22	-6.60	-9.87	-4.08							
<b>TOTALS</b>		5581.95	3057.72	12323.80	596.94	12323.80	596.94	12323.80	596.94	1788.97	23349.38	22766.12	22518.45	-2.56	-3.56	-1.10							

APPENDIX E-13

## **GLOSSARY OF TERMS**

## **APPENDIX F**

Here are some terms that the reader should know about before reading the content of this report, and the laboratory results attached.

**PARAMETER** – A measurable or quantifiable characteristic or feature. These elements can be organic (Bacteria), or inorganic (metals or salts), and/or a variety of pesticides, herbicides and PCB's.

**COLOUR** - The aesthetic objective for colour in drinking water is 5 TCU (True Colour Units). Water can have a faint yellow/brown colour which is often caused by organic materials created by the decay of vegetation. Sometimes colour may be contributed to by Iron and Manganese compounds produced by processes occurring in natural sediments or in aquifers. The presence of organic material is the main cause of disinfection by-products when water is treated with chlorine.

**I.M.A.C (Maximum Acceptable Concentration)** – This is a health-related Ontario Drinking water standards established for contaminants when there are insufficient toxicological data to establish a M.A.C. with reasonable certainty, or when it is not practical to establish a M.A.C. at the desired level.

**mg/L (Milligrams per Litre)** – This is a unit of measure of the concentration of a parameter in water, sometimes called ppm (parts per million). Simply put, mg/L means one kilogram of a chemical, or contaminant, in one million kilograms (litres) of water.

**ug/L (Micrograms per Litre)** – This is a unit of measure of the concentration of a parameter in water, sometimes called ppb (parts per billion). Simply put, ug/L means one kilogram of a chemical, or contaminant, in one billion kilograms (litres) of water.  
1000ug/L = 1 mg/L

**ng/L ( Nanograms per Litre)** – This is a unit of measure of the concentration of a parameter in water, sometimes called ppt (parts per Trillion). Simply put, ng/L means one kilogram of a chemical, or contaminant, in one Trillion kilograms (litres) of water.  
1000 ng/L = 1ug/L

**pg/L (Picograms per Litre)** – This is a unit of measure of the concentration of a parameter in water, sometimes called ppq (parts per quadrillion). Simply put, pg/L means one kilogram of a chemical, or contaminant, in one thousand trillion kilograms (litres) of water. 1000pg/L = 1 ng/L

**pH** – pH is a parameter that indicates the acidity of a water sample. The operational guideline recommended in drinking water is to maintain a pH between 6.5 and 8.5. The principal objective in controlling pH is to produce a water that is neither corrosive nor produces incrustation. At pH levels above 8.5, mineral incrustations and bitter tastes can occur. Corrosion is commonly associated with pH levels below 6.5 and elevated levels of certain undesirable chemical parameters. With pH levels above 8.5, there is a progressive decrease in the efficiency of chlorine disinfection and alum coagulation.

**Temperature** – An aesthetic objective is set for maximum water temperature to aid in selection of the best water source or the best placement for a water intake. It is desirable that the temperature of drinking water should not exceed 15 °C because of the palatability of water is enhanced by its coolness. Low water temperatures offer a number of other benefits. A temperature below 15 °C will tend to reduce the growth of nuisance organisms and minimize associated taste, colour, odour and corrosion problems. In the summer and fall, water temperatures may increase in the distributed water due to the warming of the soil. Low temperature facilitates maintenance of a free chlorine residual by reducing the rates of decay of the chlorine.

**THMs (TRICHALOMETHANES)** – The M.A.C. for THMs in drinking water is 0.10 mg/L based on a four quarter moving annual average of test results. THMs are the most widely occurring synthetic organics found in chlorinated drinking water. The four most commonly detected THMs in drinking water are chloroform, bromodichloromethane, chlorodibromomethane and bromoform. The principal source of the THMs in drinking water is the chemical reaction of chlorine with naturally occurring organics left in the water after filtration.

**TURBIDITY** - The M.A.C. for turbidity in drinking water is 1.0 FTU (Formazin Turbidity Unit) or 1.0 NTU (Nephelometric Turbidity Units) for water entering the distribution system but much lower turbidity around less than 0.1 are commonly continuously attained in well operated treatment plants. Turbidity measurements are made frequently to confirm the existence of good operating conditions at all surface water treatment plants and at some ground water plants.

An appearance related aesthetic objective of 5 FTU or NTU has been set for water consumers' Taps. Turbidity higher than 5 FTU or NTU taken at consumers' taps generally indicates severe local corrosion and/or poor bacteriological control due to loss of chlorine residual.

Turbidity in water is caused by the presence of suspended tiny particles that scatter light and make the water appear cloudy. These particles are made from matter such as clay, silt, spores, plankton and other microorganisms. The most important health related effect of turbidity is interference with disinfection and with the maintenance of chlorine residual. Viable coli form bacteria have been detected in waters with the turbidity higher than 3.8 NTU or FTU even in the presence of free chlorine residuals of up to 0.5 mg/L and after a contact time in excess of 30 minutes. Outbreaks of disease traced to chlorinated water supplies have been associated with high turbidity

